

Class I General Permit G65-C Registration to Construct



for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to
construct the stationary sources of air pollutants identified herein in accordance
with all terms and conditions of General Permit G65-C.*

G65-C549

Issued to:
Cellco Partnership dba Verizon Wireless
Ronceverte
025-00108

A blue ink signature of William F. Durham, written over a horizontal line.

William F. Durham
Director

Issued: April 15, 2015 • Effective: April 15, 2015

Facility Location: Ronceverte, Greenbrier County, West Virginia
Mailing Address: 15001 Jefferson Avenue, Newport News, VA 23603
Facility Description: Wireless Communications Facility
SIC Codes: 4812
UTM Coordinates: 547.163 km Easting • 4177.170 km Northing • Zone 17
Registration Type: Construction
Description of Change: "After-the-fact" Construction of an Emergency Generator

Subject to 40CFR60 Subpart IIII? **Yes** Certified? **Yes**

Subject to 40CFR60 Subpart JJJJ? **No**

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class I General Permit G65-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	John Deere 4024HF285	2013	80 bhp / 1800 rpm
TO1	Fuel Tank	2013	210 Gallons

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide	
	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	0.50	0.13	0.12	0.03