

*West Virginia Department of Environmental Protection*  
*Earl Ray Tomblin*  
*Governor*

*Division of Air Quality*

*Randy C. Huffman*  
*Cabinet Secretary*

# Class II General Permit G60-C Registration to Construct



for the  
Prevention and Control of Air Pollution in regard to the  
Construction, Modification, Relocation, Administrative Update and  
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to  
construct the stationary sources of air pollutants identified herein in accordance  
with all terms and conditions of General Permit G60-C.*

**G60-C069**

**Issued to:**  
**Williams Ohio Valley Midstream LLC**  
**Moundsville Natural Gas Liquids Fractionation Plant**  
**051-00141**

A handwritten signature in blue ink, appearing to read "William F. Durham", written over a horizontal line.

*William F. Durham*  
*Director*

*Issued: March 31, 2015*

Facility Location: 2 miles West-Southwest of Moundsville in Marshall County, West Virginia  
Mailing Address: Park Place Corporate Center 2, 2000 Commerce Drive Pittsburgh, PA 15275  
Facility Description: Propane-fired Emergency Generator  
SIC Code: 1321 – Natural Gas Liquids  
NAICS Code: 211112 – Natural Gas Liquid Extraction  
UTM Coordinates: 517.35 km Easting • 4,418.11 km Northing • Zone 17S  
Registration Type: Construction  
Description of Change: Installation of one (1), 49.2 bhp (36.7 kW) Kohler Model 25REZG generator/engine set fueled by propane. The generator will be used to supply power during an emergency. It will be operated a maximum of 500 hr/yr. Note that this Class II General Permit required a public notice.

Subject to 40CFR60 Subpart IIII? No.  
Subject to 40CFR60 Subpart JJJJ? Yes.

Certified? Yes.

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [ §§ 22B-1-1 et seq. ], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is subject to 45CSR30. Changes authorized by this permit must also be incorporated into the facility's Title V operating permit. Commencement date of any operation authorized by this permit shall be determined by the appropriate timing limitations associated with Title V permit revisions per 45 CSR 30.*

---

*Unless otherwise stated WVDEP DAQ did not determine whether the permittee is subject to an area source air toxics standard requiring Generally Achievable Control Technology (GACT) promulgated after January 1, 2007 pursuant to 40 CFR 63, including the area source air toxics provisions of 40 CFR 63, Subpart ZZZZ.*

**All registered facilities under Class II General Permit G60-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.**

The following sections of Class II General Permit G60-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

Installation of one (1), 49.2 bhp (36.7 kW) Kohler Model 25REZG generator/engine set fueled by propane.

**Emission Units**

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1 (6S)	Kohler 25REZG, Rich Burn Four Stroke, Liquid Propane Gas (Manufactured November 2012) (49.2 HP; 36.7 kW)	2015	49.2 / 1800

**Reciprocating Internal Combustion Engines (R.I.C.E.) Information**

Emission Unit ID	Subject to 40CFR60 Subpart IIII?	Subject to 40CFR60 Subpart JJJJ?	Subject to Sections 5.1.4/5.2.1 (Catalytic Reduction Device)
EG-1 (6S)	No	Yes	No

**Emission Limitations**

Emission Unit	Pollutant	Maximum Hourly Emissions (lb/hr)	<sup>(1)</sup> Maximum Annual Emissions (tpy)
EG-1 (6S) Kohler 25REZG, Rich Burn Four Stroke, Liquid Propane Gas (49.2 HP; 36.7 kW)	Nitrogen Oxides (NOx)	1.08	0.27
	Carbon Monoxide (CO)	41.98	10.49

(1) Basic on operating the engine 500 hours per year.