



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475 • FAX: 304/926-0479

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

April 19, 2016

Robert J. Fehrenbacher
The Chemours Company FC, LLC
P.O. Box 1217
Washington, WV 26181

RE: Permit Applicability Determination
The Chemours Company FC, LLC
Washington Works
Determination No. PD16-027
Plant ID No. 10700182

Dear Mr. Fehrenbacher:

It has been determined that a permit will not be required under 45CSR13 for your proposed addition of a new 1,000 gasoline storage tank (VGDT) to be used to dispense gasoline fuel into vehicles or containers in the Facilities, Construction, and Support Area. This determination is based on information included with your permit determination form dated April 13, 2016 and received on April 15, 2016, which indicates that there will be an emissions increase of VOC's of 10.4 pounds per hour and 0.57 tons per year which is less than the six pounds per hour or ten tons per year or more, or 144 pounds per day of criteria pollutant. Additionally, there will be an increase in Hazardous Air Pollutants (HAPs) of 0.64 pounds per hour and 0.035 tons per year which is less than the two pounds per hour or five tons per year or more. The tank is subject to 45CSR§21-23.2.a.1 which requires that the tank be equipped with a functional submerged fill and 45CSR§21-23.3 which requires daily recordkeeping of gasoline delivered to the site and that these records be kept for a minimum of 3 years. As this does not meet the definition of a substantive requirement of an emission control rule under 45CSR§13-2.24.a, no permit is needed for the addition of the gasoline tank.. It is recommended that you modify your Part 12 of 14 Title V Permit to add this tank to the equipment table and add the applicable rule 21 requirements. .

Please bear in mind, however, that any additional changes to the proposed facility may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 ext. 1208 or michael.egnor@wv.gov.

Sincerely,


Mike Egnor
Engineer

Promoting a healthy environment.