



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475 • FAX: 304/926-0479

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

July 29, 2015

Colonel Joseph P. Stephens
Construction and Facilities Management Officer
West Virginia Army National Guard
1703 Coonskin Drive
Charleston, WV 25311

RE: Permit Applicability Determination
West Virginia Army National Guard
Logan-Mingo Readiness Center
Determination No. PD15-053
Plant ID No. 045-00147

Dear Colonel Stephens:

It has been determined that a permit will not be required under 45CSR13 for your proposed construction of a emergency generator. This determination is based on information included with your permit determination form dated June 30, 2015, and received on July 15, 2015, which indicates that the increase in emissions will not exceed two (2) lbs/hr OR five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour AND ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 ext. 1214.

Sincerely,

Edward S. Andrews, P.E.
Engineer

c: Mr. Phillip Emmerth, State Environment Specialist