



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street, S.E.  
Charleston, WV 25304

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

February 24, 2015

Michael Knabe  
Real Estate Specialist, Midwest Area  
Crown Castle Solutions Corp.  
2000 Corporate Dr.  
Canonsburg, PA 15317

Re: Permit Applicability Determination  
WVU DAS Hub, Morgantown  
Monongalia County, WV  
Determination No. PD15-013  
Plant ID No. 061-00216

Dear Mr. Knabe:

It has been determined that a permit will not be required for your proposed installation and operation of a 237 hp diesel fired emergency generator set at the above referenced facility. This determination is based on information included with your Permit Determination Form (PDF) received on February 10, 2015, which indicates that the increase in emissions will not exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility, may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer