west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

February 11, 2016

CERTIFIED MAIL
91 7199 9991 7034 1379 8266

Jack Henson
MEP Engineer
900 Circle 75 Parkway, Ste. 1080
Atlanta, GA 30339

RE: Approved Registration G65-C558
Bio-Medical Applications of WV, Inc. dba Fresenius
Medical Care Man Dialysis
FMC Man Dialysis
Plant ID No. 045-00152

Dear Mr. Henson:

The Director has determined that the submitted Registration Application and construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G65-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.5.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.
Engineer

Enclosures: General Permit Registration G65-C558
General Permit G65-C

West Virginia Department of Environmental Protection

Earl Ray Tomblin
Governor

Division of Air Quality

Randy C. Huffman
Cabinet Secretary

Class I General Permit
G65-C Registration to Construct

for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

The permittee identified at the facility listed below is authorized to construct the stationary sources of air pollutants identified herein in accordance with all terms and conditions of General Permit G65-C.

G65-C558

Issued to:
Bio-Medical Applications of WV, Inc. dba Fresenius Medical Care Man Dialysis
FMC – Man Dialysis
045-00152

William F. Durham
Director

Issued: February 11, 2016 • Effective: February 11, 2016

Facility Location:	Man, Logan County, West Virginia
Mailing Address:	900 Circle 75 Parkway, Ste. 1080, Atlanta, GA 30339
Facility Description:	Kidney Dialysis Clinic
SIC Codes:	8092
UTM Coordinates:	423.600 km Easting • 4176.212 km Northing • Zone 17
Registration Type:	Construction
Description of Change:	Construction of an Emergency Generator

Subject to 40CFR60 Subpart IIII? **Yes** Certified? **Yes**
Subject to 40CFR60 Subpart JJJJ? **No**

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class I General Permit G65-C apply to the registrant:

Section 5	Reciprocating Internal Combustion Engines (R.I.C.E.)	☒
Section 6	Tanks	☒
Section 7	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)	☒
Section 8	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)	☐

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	John Deere 6068HFG82	2015	284 bhp / 1800 rpm
TO1	Fuel Tank	2015	400 Gallons

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide	
	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	1.87	0.47	1.63	0.41