



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone: 304 926 0475

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

February 5, 2016

Mr. Stacey Dreyer
Manager RF Performance and Operations
WV Alliance, LC, dba Ntelos
500 Summers Street
Charleston, WV 25301

Re: CH144 Crooked Creek Facility
Putnam County, WV
Facility ID No. 079-00178
Determination No. PD16-015
Registration G65-C417

Dear Mr. Dreyer:

Pursuant to your Permit Determination Form (PDF) submittal received on January 28, 2016, General Permit Registration G65-C417, issued on September 23, 2013, has been placed as inactive.

Your PDF submittal indicated that emergency generator's 36 hp Kabuta V2203-M engine, that was manufactured in 2012, was EPA Tier 4 Certified. Additionally, the uncontrolled emissions from emergency generator are less than six (6) pounds per hour and ten (10) tons per year. Therefore, a permit is not required for the emergency generator and the exiting General Permit Registration G65-C417 will be placed as inactive.

Please bear in mind, any future modification or construction may require a permit pursuant to 45CSR13.

Sincerely,

William F. Durham
Director

WFD/WTR

c: file room