



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street, S.E.  
Charleston, WV 25304

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

January 12, 2016

John McKitrick  
Operations Manager  
Clearon Corporation  
95 MacCorkle Avenue  
South Charleston, WV 25303

Re: Permit Applicability Determination  
South Charleston Facility  
Kanawha County, WV  
Determination No. PD15-107  
Plant ID No. 039-00011

Dear Mr. McKitrick:

It has been determined that a permit will not be required under 45CSR13 for the proposed replacement of an existing 20,000 gallon sodium bisulfate tank with a new 18,500 gallon sodium bisulfate tank at the above referenced facility. This determination is based on information included with your Permit Determination Form (PDF) received on December 17, 2015, which indicates that the increase in emissions will not exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility, may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer