



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone 304/926-0475

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
www.dep.wv.gov

January 12, 2015

CERTIFIED MAIL  
91 7199 9991 7034 1379 8235

Jack Henson  
MEP Engineer  
900 Circle 75 Parkway, Ste. 1080  
Atlanta, GA 30339

RE: Approved Registration G65-C557  
Bio-Medical Applications of WV dba Bio-Med App of  
Morgantown  
BMA Morgantown  
Plant ID No. 061-00224

Dear Mr. Henson:

The Director has determined that the submitted Registration Application and construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G65-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.5.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer

Enclosures: General Permit Registration G65-C557  
General Permit G65-C

*West Virginia Department of Environmental Protection*  
Earl Ray Tomblin  
Governor

*Division of Air Quality*

Randy C. Huffman  
Cabinet Secretary

# Class I General Permit G65-C Registration to Construct



for the  
Prevention and Control of Air Pollution in regard to the  
Construction, Modification, Relocation, Administrative Update and  
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to  
construct the stationary sources of air pollutants identified herein in accordance  
with all terms and conditions of General Permit G65-C.*

**G65-C557**

Issued to:  
**Bio-Medical Applications of WV dba Bio-Med App of Morgantown**  
**BMA Morgantown**  
**061-00224**

A blue ink signature of William F. Durham, written in a cursive style, positioned above a horizontal line.

*William F. Durham*  
Director

*Issued: January 12, 2016 • Effective: January 12, 2016*

Facility Location: Morgantown, Monongalia County, West Virginia  
Mailing Address: 900 Circle 75 Parkway, Ste. 1080, Atlanta, GA 30339  
Facility Description: Kidney Dialysis Clinic  
SIC Codes: 8092  
UTM Coordinates: 438.454 km Easting • 4384.543 km Northing • Zone 17  
Registration Type: Construction  
Description of Change: Construction of an Emergency Generator

Subject to 40CFR60 Subpart III? Yes Certified? Yes  
Subject to 40CFR60 Subpart JJJ? No

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is not subject to 45CSR30.*

---

**All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.**

The following sections of Class I General Permit G65-C apply to the registrant:

- Section 5      Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6      Tanks
- Section 7      Standards of Performance for Stationary Compression Ignition  
Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8      Standards of Performance for Stationary Spark Ignition Internal  
Combustion Engines (40CFR60 Subpart JJJJ)

**Emission Units**

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	John Deere 6068HF485	2015	315 bhp / 1800 rpm
TO1	Fuel Tank	2015	400 Gallons

**Emission Limitations**

Source ID#	Nitrogen Oxides		Carbon Monoxide	
	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	2.07	0.52	1.81	0.45