



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street, S.E.  
Charleston, WV 25304

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

January 4, 2016

Jeff Murphy  
VP and General Manager Dominion East Ohio  
Dominion Transmission, Inc.  
925 White Oaks Blvd.  
Bridgeport, WV 26330

Re: Permit Applicability Determination  
Parkersburg City Plant  
Wood County, WV  
Determination No. PD15-100  
Plant ID No. 107-00184

Dear Mr. Murphy:

It has been determined that a permit will not be required for the installation and operation of one Cummins Model KTA19G generator set utilizing a 530 BHP @ 1,800 RPM natural gas fired engine at the above referenced facility. This determination is based on information included with your Permit Determination Form (PDF) received on November 30, 2015, which indicates that the increase in emissions will not exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility, may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer