



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

July 7, 2016

CERTIFIED MAIL
91 7199 9991 7034 1379 8334

David R. Bochenek
1301 Piedmont Road
Charleston, WV 25301

RE: Approved Registration G65-C298A
Sinclair Media III, Inc.
WCHS/WVAH Studio Building
Plant ID No. 045-00152

Dear Mr. Bochenek:

The Director has determined that the submitted Registration Application and construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G65-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.5.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.
Engineer

Enclosures: General Permit Registration G65-C298A
General Permit G65-C

Facility Location: Charleston, Kanawha County, West Virginia
Mailing Address: 1301 Piedmont Road, Charleston, WV 25301
Facility Description: Television Studio
SIC Codes: 4833
UTM Coordinates: 4244.648 km Easting • 445.979 km Northing • Zone 17
Registration Type: Construction
Description of Change: Replacement of an Emergency Generator

Subject to 40CFR60 Subpart IIII? **Yes**
Subject to 40CFR60 Subpart JJJJ? **No**

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class I General Permit G65-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition
Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal
Combustion Engines (40CFR60 Subpart JJJJ)

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-2	Caterpillar C9	2016	398 bhp / 1,800 rpm
T02	Diesel Storage Tank	2016	730 gallons

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide		Volatile Organic Compounds	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EG-2	2.54	0.60	0.35	0.10	0.09	0.02