West Virginia Department of Environmental Protection
Division of Air Quality

Earl Ray Tomblin
Governor

Randy C. Huffman
Cabinet Secretary

Permit to Modify

R13-3042

This permit is issued in accordance with the West Virginia Air Pollution Control Act (West Virginia Code §§ 22-5-1 et seq.) and 45 C.S.R. 13 — Permits for Construction, Modification, Relocation and Operation of Stationary Sources of Air Pollutants, Notification Requirements, Temporary Permits, General Permits and Procedures for Evaluation. The permittee identified at the facility listed below is authorized to construct the stationary sources of air pollutants identified herein in accordance with all terms and conditions of this permit.

Issued to:

Equitable Production Company
Moss Station
097-00055

John A. Benedict
Director

Issued: DRAFT • Effective: DRAFT

This permit will supercede and replace General Permit Registration G30-A070

Facility Location:	Ellamore, Upshur County, West Virginia
Mailing Address:	625 Liberty Ave. Suite 1700 Pittsburgh, PA 15222
Facility Description:	Natural gas well pad and compressor
NAICS Codes:	211111
UTM Coordinates:	576.692 km Easting • 4,305.193 km Northing • Zone 17
Permit Type:	Modification

Description of Change:

Construction and operation of support facilities associated with a natural gas production wellpad. Additionally, replacement of the existing compressor engine currently registered under General Permit G30-A.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

Table of Contents

1.0. Emission Units 3

2.0. General Conditions 4
- 2.1. Definitions 4
- 2.2. Acronyms 4
- 2.3. Authority 5
- 2.4. Term and Renewal 5
- 2.5. Duty to Comply 5
- 2.6. Duty to Provide Information 5
- 2.7. Duty to Supplement and Correct Information 6
- 2.8. Administrative Permit Update 6
- 2.9. Permit Modification 6
- 2.10. Major Permit Modification 6
- 2.11. Inspection and Entry 6
- 2.12. Emergency 6
- 2.13. Need to Halt or Reduce Activity Not a Defense 7
- 2.14. Suspension of Activities 7
- 2.15. Property Rights 7
- 2.16. Severability 8
- 2.17. Transferability 8
- 2.18. Notification Requirements 8
- 2.19. Credible Evidence 8

3.0. Facility-Wide Requirements 9
- 3.1. Limitations and Standards 9
- 3.2. Monitoring Requirements 9
- 3.3. Testing Requirements 9
- 3.4. Recordkeeping Requirements 11
- 3.5. Reporting Requirements 11

4.0. Source-Specific Requirements 13
- 4.1. Limitations and Standards 13
- 4.2. Testing Requirements 15
- 4.3. Monitoring and Recordkeeping Requirements 15
- 4.4. Reporting Requirements 16

CERTIFICATION OF DATA ACCURACY **17**

1.0 Emission Units

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device
S001	E001	Compressor Engine	2013	145 hp	N
S002	E002	Produced Fluids Storage Tank	2004	4200 gal	N
S003	E003	Lube Oil Tank	2004	550 gal	N
S004	E004	Compressor Oil Tank	2004	30 gal	N
S005	E005	Inhibitor Tank	2004	130 gal	N
S006	E006	Inhibitor Tank	2004	130 gal	N
S007	E007	Soap Tank	2004	250 gal	N

2.0. General Conditions

2.1. Definitions

2.1.1. All references to the "West Virginia Air Pollution Control Act" or the "Air Pollution Control Act" mean those provisions contained in W.Va. Code §§ 22-5-1 to 22-5-18.

2.1.2. The "Clean Air Act" means those provisions contained in 42 U.S.C. §§ 7401 to 7671q, and regulations promulgated thereunder.

2.1.3. "Secretary" means the Secretary of the Department of Environmental Protection or such other person to whom the Secretary has delegated authority or duties pursuant to W.Va. Code §§ 22-1-6 or 22-1-8 (45 CSR § 30-2.12.). The Director of the Division of Air Quality is the Secretary's designated representative for the purposes of this permit.

2.2. Acronyms

CAAA	Clean Air Act Amendments	**NO_x**	Nitrogen Oxides
CBI	Confidential Business Information	**NSPS**	New Source Performance Standards
CEM	Continuous Emission Monitor	**PM**	Particulate Matter
CES	Certified Emission Statement	**$PM_{2.5}$**	Particulate Matter less than 2.5µm in diameter
C.F.R. *or* CFR	Code of Federal Regulations		
CO	Carbon Monoxide	**PM_{10}**	Particulate Matter less than 10µm in diameter
C.S.R. *or* CSR	Codes of State Rules		
DAQ	Division of Air Quality	**Ppb**	Pounds per Batch
DEP	Department of Environmental Protection	**pph**	Pounds per Hour
		ppm	Parts per Million
dscm	Dry Standard Cubic Meter	**Ppmv or ppmv**	Parts per million by volume
FOIA	Freedom of Information Act		
HAP	Hazardous Air Pollutant	**PSD**	Prevention of Significant Deterioration
HON	Hazardous Organic NESHAP		
HP	Horsepower	**psi**	Pounds per Square Inch
lbs/hr	Pounds per Hour	**SIC**	Standard Industrial Classification
LDAR	Leak Detection and Repair		
M	Thousand	**SIP**	State Implementation Plan
MACT	Maximum Achievable Control Technology	**SO_2**	Sulfur Dioxide
		TAP	Toxic Air Pollutant
MDHI	Maximum Design Heat Input	**TPY**	Tons per Year
MM	Million	**TRS**	Total Reduced Sulfur
MMBtu/hr *or* mmbtu/hr	Million British Thermal Units per Hour	**TSP**	Total Suspended Particulate
		USEPA	United States Environmental Protection Agency
MMCF/hr *or* mmcf/hr	Million Cubic Feet per Hour		
NA	Not Applicable	**UTM**	Universal Transverse Mercator
NAAQS	National Ambient Air Quality Standards	**VEE**	Visual Emissions Evaluation
		VOC	Volatile Organic Compounds
NESHAPS	National Emissions Standards for Hazardous Air Pollutants	**VOL**	Volatile Organic Liquids

2.3. Authority

This permit is issued in accordance with West Virginia Air Pollution Control Law W.Va. Code §§22-5-1 et seq. and the following Legislative Rules promulgated thereunder:

2.3.1. 45CSR13 – *Permits for Construction, Modification, Relocation and Operation of Stationary Sources of Air Pollutants, Notification Requirements, Temporary Permits, General Permits and Procedures for Evaluation;*

2.4. Term and Renewal

2.4.1. This permit supercedes and replaces previously issued General Permit Registration G30-A070. This permit shall remain valid, continuous and in effect unless it is revised, suspended, revoked or otherwise changed under an applicable provision of 45CSR13 or any applicable legislative rule.

2.5. Duty to Comply

2.5.1. The permitted facility shall be constructed and operated in accordance with the plans and specifications filed in Permit Application R13-3042 and any modifications, administrative updates, or amendments thereto. The Secretary may suspend or revoke a permit if the plans and specifications upon which the approval was based are not adhered to;
[45CSR§§13-5.11 and 13-10.3]

2.5.2. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the West Virginia Code and the Clean Air Act and is grounds for enforcement action by the Secretary or USEPA;

2.5.3. Violations of any of the conditions contained in this permit, or incorporated herein by reference, may subject the permittee to civil and/or criminal penalties for each violation and further action or remedies as provided by West Virginia Code 22-5-6 and 22-5-7;

2.5.4. Approval of this permit does not relieve the permittee herein of the responsibility to apply for and obtain all other permits, licenses and/or approvals from other agencies; i.e., local, state and federal, which may have jurisdiction over the construction and/or operation of the source(s) and/or facility herein permitted.

2.6. Duty to Provide Information

The permittee shall furnish to the Secretary within a reasonable time any information the Secretary may request in writing to determine whether cause exists for administratively updating, modifying, revoking or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Secretary copies of records to be kept by the permittee. For information claimed to be confidential, the permittee shall furnish such records to the Secretary along with a claim of confidentiality in accordance with 45CSR31. If confidential information is to be sent to USEPA, the permittee shall directly provide such information to USEPA along with a claim of confidentiality in accordance with 40 C.F.R. Part 2.

2.7. Duty to Supplement and Correct Information

Upon becoming aware of a failure to submit any relevant facts or a submittal of incorrect information in any permit application, the permittee shall promptly submit to the Secretary such supplemental facts or corrected information.

2.8. Administrative Update

The permittee may request an administrative update to this permit as defined in and according to the procedures specified in 45CSR13.
[45CSR§13-4]

2.9. Permit Modification

The permittee may request a minor modification to this permit as defined in and according to the procedures specified in 45CSR13.
[45CSR§13-5.4.]

2.10. Major Permit Modification

The permittee may request a major modification as defined in and according to the procedures specified in 45CSR14 or 45CSR19, as appropriate.
[45CSR§13-5.1]

2.11. Inspection and Entry

The permittee shall allow any authorized representative of the Secretary, upon the presentation of credentials and other documents as may be required by law, to perform the following:

a. At all reasonable times (including all times in which the facility is in operation) enter upon the permittee's premises where a source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;

b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;

c. Inspect at reasonable times (including all times in which the facility is in operation) any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit;

d. Sample or monitor at reasonable times substances or parameters to determine compliance with the permit or applicable requirements or ascertain the amounts and types of air pollutants discharged.

2.12. Emergency

2.12.1. An "emergency" means any situation arising from sudden and reasonable unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission

limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

2.12.2. Effect of any emergency. An emergency constitutes an affirmative defense to an action brought for noncompliance with such technology-based emission limitations if the conditions of Section 2.12.3 are not met.

2.12.3. The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;

b. The permitted facility was at the time being properly operated;

c. During the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and,

d. The permittee submitted notice of the emergency to the Secretary within one (1) working day of the time when emission limitations were exceeded due to the emergency and made a request for variance, and as applicable rules provide. This notice must contain a detailed description of the emergency, any steps taken to mitigate emission, and corrective actions taken.

2.12.4. In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof.

2.12.5. The provisions of this section are in addition to any emergency or upset provision contained in any applicable requirement.

2.13. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a permittee in an enforcement action that it should have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. However, nothing in this paragraph shall be construed as precluding consideration of a need to halt or reduce activity as a mitigating factor in determining penalties for noncompliance if the health, safety, or environmental impacts of halting or reducing operations would be more serious than the impacts of continued operations.

2.14. Suspension of Activities

In the event the permittee should deem it necessary to suspend, for a period in excess of sixty (60) consecutive calendar days, the operations authorized by this permit, the permittee shall notify the Secretary, in writing, within two (2) calendar weeks of the passing of the sixtieth (60) day of the suspension period.

2.15. Property Rights

This permit does not convey any property rights of any sort or any exclusive privilege.

2.16. Severability

The provisions of this permit are severable and should any provision(s) be declared by a court of competent jurisdiction to be invalid or unenforceable, all other provisions shall remain in full force and effect.

2.17. Transferability

This permit is transferable in accordance with the requirements outlined in Section 10.1 of 45CSR13. **[45CSR§13-10.1]**

2.18. Notification Requirements

The permittee shall notify the Secretary, in writing, no later than thirty (30) calendar days after the actual startup of the operations authorized under this permit.

2.19. Credible Evidence

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defense otherwise available to the permittee including, but not limited to, any challenge to the credible evidence rule in the context of any future proceeding.

3.0. Facility-Wide Requirements

3.1. Limitations and Standards

3.1.1. **Open burning.** The open burning of refuse by any person, firm, corporation, association or public agency is prohibited except as noted in 45CSR§6-3.1.
[45CSR§6-3.1.]

3.1.2. **Open burning exemptions.** The exemptions listed in 45CSR§6-3.1 are subject to the following stipulation: Upon notification by the Secretary, no person shall cause, suffer, allow or permit any form of open burning during existing or predicted periods of atmospheric stagnation. Notification shall be made by such means as the Secretary may deem necessary and feasible.
[45CSR§6-3.2.]

3.1.3. **Asbestos.** The permittee is responsible for thoroughly inspecting the facility, or part of the facility, prior to commencement of demolition or renovation for the presence of asbestos and complying with 40 C.F.R. § 61.145, 40 C.F.R. § 61.148, and 40 C.F.R. § 61.150. The permittee, owner, or operator must notify the Secretary at least ten (10) working days prior to the commencement of any asbestos removal on the forms prescribed by the Secretary if the permittee is subject to the notification requirements of 40 C.F.R. § 61.145(b)(3)(i). The USEPA, the Division of Waste Management and the Bureau for Public Health - Environmental Health require a copy of this notice to be sent to them.
[40CFR§61.145(b) and 45CSR§34]

3.1.4. **Odor.** No person shall cause, suffer, allow or permit the discharge of air pollutants which cause or contribute to an objectionable odor at any location occupied by the public.
[45CSR§4-3.1 State-Enforceable only.]

3.1.5. **Permanent shutdown.** A source which has not operated at least 500 hours in one 12-month period within the previous five (5) year time period may be considered permanently shutdown, unless such source can provide to the Secretary, with reasonable specificity, information to the contrary. All permits may be modified or revoked and/or reapplication or application for new permits may be required for any source determined to be permanently shutdown.
[45CSR§13-10.5.]

3.1.6. **Standby plan for reducing emissions.** When requested by the Secretary, the permittee shall prepare standby plans for reducing the emissions of air pollutants in accordance with the objectives set forth in Tables I, II, and III of 45 C.S.R. 11.
[45CSR§11-5.2.]

3.2. Monitoring Requirements

[Reserved]

3.3. Testing Requirements

3.3.1. **Stack testing.** As per provisions set forth in this permit or as otherwise required by the Secretary, in accordance with the West Virginia Code, underlying regulations, permits and orders, the permittee shall conduct test(s) to determine compliance with the emission limitations set forth in

this permit and/or established or set forth in underlying documents. The Secretary, or his duly authorized representative, may at his option witness or conduct such test(s). Should the Secretary exercise his option to conduct such test(s), the operator shall provide all necessary sampling connections and sampling ports to be located in such manner as the Secretary may require, power for test equipment and the required safety equipment, such as scaffolding, railings and ladders, to comply with generally accepted good safety practices. Such tests shall be conducted in accordance with the methods and procedures set forth in this permit or as otherwise approved or specified by the Secretary in accordance with the following:

a. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with 40 C.F.R. Parts 60, 61, and 63 in accordance with the Secretary's delegated authority and any established equivalency determination methods which are applicable. If a testing method is specified or approved which effectively replaces a test method specified in the permit, the permit may be revised in accordance with 45CSR§13-4 or 45CSR§13-5.4 as applicable.

b. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with applicable requirements which do not involve federal delegation. In specifying or approving such alternative testing to the test methods, the Secretary, to the extent possible, shall utilize the same equivalency criteria as would be used in approving such changes under Section 3.3.1.a. of this permit. If a testing method is specified or approved which effectively replaces a test method specified in the permit, the permit may be revised in accordance with 45CSR§13-4 or 45CSR§13-5.4 as applicable.

c. All periodic tests to determine mass emission limits from or air pollutant concentrations in discharge stacks and such other tests as specified in this permit shall be conducted in accordance with an approved test protocol. Unless previously approved, such protocols shall be submitted to the Secretary in writing at least thirty (30) days prior to any testing and shall contain the information set forth by the Secretary. In addition, the permittee shall notify the Secretary at least fifteen (15) days prior to any testing so the Secretary may have the opportunity to observe such tests. This notification shall include the actual date and time during which the test will be conducted and, if appropriate, verification that the tests will fully conform to a referenced protocol previously approved by the Secretary.

d. The permittee shall submit a report of the results of the stack test within sixty (60) days of completion of the test. The test report shall provide the information necessary to document the objectives of the test and to determine whether proper procedures were used to accomplish these objectives. The report shall include the following: the certification described in paragraph 3.5.1.; a statement of compliance status, also signed by a responsible official; and, a summary of conditions which form the basis for the compliance status evaluation. The summary of conditions shall include the following:

    1. The permit or rule evaluated, with the citation number and language;
    2. The result of the test for each permit or rule condition; and,
    3. A statement of compliance or noncompliance with each permit or rule condition.

    [WV Code § 22-5-4(a)(14-15) and 45CSR13]

3.4. Recordkeeping Requirements

3.4.1. **Retention of records.** The permittee shall maintain records of all information (including monitoring data, support information, reports and notifications) required by this permit recorded in a form suitable and readily available for expeditious inspection and review. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation. The files shall be maintained for at least five (5) years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. At a minimum, the most recent two (2) years of data shall be maintained on site. The remaining three (3) years of data may be maintained off site, but must remain accessible within a reasonable time. Where appropriate, the permittee may maintain records electronically (on a computer, on computer floppy disks, CDs, DVDs, or magnetic tape disks), on microfilm, or on microfiche.

3.4.2. **Odors.** For the purposes of 45CSR4, the permittee shall maintain a record of all odor complaints received, any investigation performed in response to such a complaint, and any responsive action(s) taken.
[45CSR§4. *State-Enforceable only.*]

3.5. Reporting Requirements

3.5.1. **Responsible official.** Any application form, report, or compliance certification required by this permit to be submitted to the DAQ and/or USEPA shall contain a certification by the responsible official that states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

3.5.2. **Confidential information.** A permittee may request confidential treatment for the submission of reporting required by this permit pursuant to the limitations and procedures of W.Va. Code § 22-5-10 and 45CSR31.

3.5.3. **Correspondence.** All notices, requests, demands, submissions and other communications required or permitted to be made to the Secretary of DEP and/or USEPA shall be made in writing and shall be deemed to have been duly given when delivered by hand, or mailed first class with postage prepaid to the address(es) set forth below or to such other person or address as the Secretary of the Department of Environmental Protection may designate:

If to the DAQ:	**If to the USEPA:**
Director WVDEP Division of Air Quality 601 57th Street, SE Charleston, WV 25304-2345	Associate Director Office of Air Enforcement and Compliance Assistance (3AP20) U. S. Environmental Protection Agency Region III 1650 Arch Street Philadelphia, PA 19103-2029

3.5.4. **Operating Fee.**

3.5.4.1. In accordance with 45CSR22 – Air Quality Management Fee Program, the permittee shall not operate nor cause to operate the permitted facility or other associated facilities on the same or contiguous sites comprising the plant without first obtaining and having in current effect a Certificate to Operate (CTO). Such Certificate to Operate (CTO) shall be renewed annually, shall be maintained on the premises for which the certificate has been issued, and shall be made immediately available for inspection by the Secretary or his/her duly authorized representative.

3.5.5. **Emission inventory.** At such time(s) as the Secretary may designate, the permittee herein shall prepare and submit an emission inventory for the previous year, addressing the emissions from the facility and/or process(es) authorized herein, in accordance with the emission inventory submittal requirements of the Division of Air Quality. After the initial submittal, the Secretary may, based upon the type and quantity of the pollutants emitted, establish a frequency other than on an annual basis.

4.0. Source-Specific Requirements

4.1. Limitations and Standards

4.1.1 Emissions from the facility shall not exceed the following:

Hourly Emissions (lb/hr)

	Compressor Engine	Fugitives	Tanks	**Total**
CO	0.64	--	--	**0.64**
NO_x	0.32	--	--	**0.32**
VOC	0.06	0.66	0.02	**0.72**
Formaldehyde	0.03	--	--	**0.03**
Benzene	0.01	--	--	**0.01**
Total HAPs	0.05	--	--	**0.05**

Annual Emissions (tons per year)

	Compressor Engine	Fugitives	Tanks	**Total**
CO	2.80	--	--	**2.80**
NO_x	1.40	--	--	**1.40**
VOC	0.28	2.87	0.09	**3.24**
Formaldehyde	0.11	--	--	**0.11**
Benzene	0.01	--	--	**0.01**
Total HAPs	0.17	--	--	**0.16**

4.1.2 Only those emission units/sources as identified in Table 1.0, with the exception of any *de minimis* sources as identified under Table 45-13B of 45CSR13, are authorized at the permitted facility. In accordance with the information filed in Permit Application R13-3042, the emission units/sources identified under Table 1.0 of this permit shall be installed, maintained, and operated so as to minimize any fugitive escape of pollutants, shall not exceed the listed maximum design capacities, and shall use the specified control devices.

4.1.3 Throughput of liquids to tank S002 shall not exceed 8,400 gallons per year based on a rolling 12 month total.

4.1.4 All condensate/liquids trucks shall be loaded using the submerged-fill method.

4.1.5 The permittee shall not exceed the number and type of components (valves, pump seals, connectors, etc.) in gas/vapor or light liquid (as applicable) listed in Attachment N of Permit Application R13-3042.

4.1.6. The Company shall install, maintain, and operate all above-ground piping, valves, pumps, etc. that service lines in the transport of potential sources of regulated air pollutants to prevent any substantive fugitive escape of regulated air pollutants. Any above-ground piping, valves, pumps, etc. that shows signs of excess wear and that have a reasonable potential for substantive fugitive emissions of regulated air pollutants shall be replaced.

4.1.7 Emissions from Compressor Engine S001 shall not exceed the following:
[40 CFR§ 60.4233(e)]

NO_x		CO		VOC	
g/HP-hr	ppm_{vd} @15% O_2	g/HP-hr	ppm_{vd} @15% O_2	g/HP-hr	ppm_{vd} @15% O_2
2.0	160	4.0	540	1.0	86

4.1.8 Each pneumatic controller affected facility constructed, modified or reconstructed on or after October 15, 2013 at a location between the wellhead and a natural gas processing plant must have a bleed rate less than or equal to 6 standard cubic feet per hour.

Each pneumatic controller affected facility at a location between the wellhead and a natural gas processing plant must be tagged with the month and year of installation, reconstruction or modification, and identification information that allows traceability to the records for that controller as required in § 60.5420(c)(4)(iii).
[40 CFR§ 60.5390(c)]

4.1.9. **Operation and Maintenance of Air Pollution Control Equipment.** The permittee shall, to the extent practicable, install, maintain, and operate all pollution control equipment listed in Section 1.0 and associated monitoring equipment in a manner consistent with safety and good air pollution control practices for minimizing emissions, or comply with any more stringent limits set forth in this permit or as set forth by any State rule, Federal regulation, or alternative control plan approved by the Secretary.
[45CSR§13-5.11.]

4.2. Testing Requirements

4.2.1. Within sixty (60) days of the issuance date of this permit, the permittee shall perform, or have performed, an analysis to determine the constituent properties of the condensate (testing done previous to permit issuance deemed to be appropriate by the Director shall be accepted). The analysis shall, at a minimum, include the same components as the analysis used to calculate storage tank emissions in Permit Application R13-3042. The sample shall be taken from the pressurized liquid stream, aqueous and organic, coming from the last separator that feeds the storage tanks. Where applicable, if the analysis shows average constituent properties that, when used to calculate emissions in the same manner as submitted in Permit Application R13-3042, result in emissions that are greater than the limits in 4.1.1, the permittee shall, within thirty (30) days of receiving the results of the analysis, submit to the Director an appropriate permit application to increase emissions.

4.2.2 The permittee shall perform an initial performance test of Compressor Engine S001 in accordance with the requirements of 40 CFR§ 60.4244.
[40 CFR§ 60.4243(b)(2)(i)]

4.3. Monitoring and Recordkeeping Requirements

4.3.1. **Record of Monitoring.** The permittee shall keep records of monitoring information that include the following:

a. The date, place as defined in this permit and time of sampling or measurements;

b. The date(s) analyses were performed;

c. The company or entity that performed the analyses;

d. The analytical techniques or methods used;

e. The results of the analyses; and

f. The operating conditions existing at the time of sampling or measurement.

4.3.2. **Record of Maintenance of Air Pollution Control Equipment.** For all pollution control equipment listed in Section 1.0, the permittee shall maintain accurate records of all required pollution control equipment inspection and/or preventative maintenance procedures.

4.3.3. **Record of Malfunctions of Air Pollution Control Equipment.** For all air pollution control equipment listed in Section 1.0, the permittee shall maintain records of the occurrence and duration of any malfunction or operational shutdown of the air pollution control equipment during which excess emissions occur. For each such case, the following information shall be recorded:

a. The equipment involved.

b. Steps taken to minimize emissions during the event.

c. The duration of the event.

d. The estimated increase in emissions during the event.

For each such case associated with an equipment malfunction, the additional information shall also be recorded:

e. The cause of the malfunction.

f. Steps taken to correct the malfunction.

g. Any changes or modifications to equipment or procedures that would help prevent future recurrences of the malfunction.

4.3.4. The permittee shall keep a maintenance plan and records of conducted maintenance of the Compressor Engine S001.
[40 CFR §60.4243(b)(2)(i)]

4.3.5 For the purposes of demonstrating compliance with maximum limit for the aggregate production of condensate/liquids from the wells set forth in 4.1.3, the permittee shall monitor and record the monthly and rolling twelve month total of condensate/liquids (in gallons) produced in the wells. Monitoring and recording the monthly and rolling twelve month total of condensate/liquids (in gallons) unloaded from the storage tanks can be used to show compliance with this requirement.

4.4. Reporting Requirements

4.4.1. The permittee shall comply with all applicable reporting requirements of 40 CFR 60 Subparts JJJJ.

CERTIFICATION OF DATA ACCURACY

I, the undersigned, hereby certify that, based on information and belief formed after reasonable inquiry, all information contained in the attached _____, representing the period beginning _____ and ending _____, and any supporting documents appended hereto, is true, accurate, and complete.

Signature[1] _____ _____
(please use blue ink) Responsible Official or Authorized Representative Date

Name and Title _____ _____
(please print or type) Name Title

Telephone No. _____ Fax No. _____

---

[1] This form shall be signed by a "Responsible Official." "Responsible Official" means one of the following:

a. For a corporation: The president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit and either:

(I) the facilities employ more than 250 persons or have a gross annual sales or expenditures exceeding $25 million (in second quarter 1980 dollars), or

(ii) the delegation of authority to such representative is approved in advance by the Director;

b. For a partnership or sole proprietorship: a general partner or the proprietor, respectively;

c. For a municipality, State, Federal, or other public entity: either a principal executive officer or ranking elected official. For the purposes of this part, a principal executive officer of a Federal agency includes the chief executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., a Regional Administrator of USEPA); or

d. The designated representative delegated with such authority and approved in advance by the Director.