



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475 • FAX: 304/926-0479

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

May 22, 2015

Dominion Transmission, Inc
Ms. Rebekah Remick
445 West Main Street
Clarksburg, WV 26301

RE: Permit Applicability Determination
Dominion Transmission, Inc
Madison City Plant
Determination No. PD15-041
Plant ID No. 005-00096

Dear Ms. Remick:

It has been determined that a permit will not be required under 45CSR13 for your proposed installation of a natural gas auxiliary generator. This determination is based on information included with your permit determination form dated April 29, 2015 and received on May 8, 2015, which indicates that the increase in emissions will not exceed two (2) lbs/hr OR five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour AND ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

This permit determination is for the installation of a natural gas auxiliary generator, Generac QT306, at the Madison City Plant, Daville, Boone County, West Virginia.

Please bear in mind, however, that any additional changes to the proposed facility may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 ext. 1258.

Sincerely,

Caraline Griffith
Permit Engineer