



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475 • FAX: 304/926-0479

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

June 9, 2015

Michael P. Nau, Plant Manager
Axens North America
74 Catalyst Drive
Belmont, WV 26134

RE: Permit Applicability Determination
Axens North America, Inc.
Belmont Facility
Determination No. PD15-046
Plant ID No. 073-00023

Dear Mr. Nau:

It has been determined that a permit will not be required under 45CSR13 to separate the exhaust from the Extrudate Tray Dryers and the Nol. 1 Calciner. This determination is based on information included with your letter dated May 18, 2015 and received on May 20, 2015, which indicates that the increase in emissions will not exceed two (2) lbs/hr OR five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour AND ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 ext. 1218.

Sincerely,

Steven R. Pursley, PE
Engineer