


Class II General Permit G60-C Registration to for a Class I Administration Update



for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to
construct the stationary sources of air pollutants identified herein in accordance
with all terms and conditions of General Permit G60-C.*

G60-C042B

Issued to:

**West Virginia Army National Guard
Camp Dawson, Kingwood, Preston County, WV
Company ID: 077-00078**

A blue ink signature of William F. Durham, written in a cursive style, positioned above a horizontal line.

William F. Durham
Director

Issued: June 17, 2015

This Class II General Permit Registration will supercede and replace G60-C042A.

Facility Location: Kingwood, Preston County, West Virginia
Mailing Address: 1001 Military Road, Kingwood, WV 26537
Facility Description: Military Training Facility
NAICS Codes: 928110
UTM Coordinates: 614.8 km Easting • 4,367.5 km Northing • Zone 17
Registration Type: Class I Administrative Update
Description of Change: This action is to remove emergency engines G1 and G2 from the registration.

Subject to 40CFR60 Subpart IIII? **Yes** (EG-3, EG-4 & EG-5 only), Certified? **Yes** (EG-3, EG-4 & EG-5 only)

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class II General Permit G60-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class II General Permit G60-C apply to the registrant:

Section 5	Reciprocating Internal Combustion Engines (R.I.C.E.)	X
Section 6	Tanks	
Section 7	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart III)	X
Section 8	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)	

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-3	Cummins QSK60-G6 NR2 2000 kW Diesel Engine Manufactured 2013	2014	2,919 Bhp/1800 rpm
EG-4	350DFEG 60 Hz Diesel Generator Set Cummins Inc. QSX15-G9 NR2 350 kW Diesel Engine Manufactured 2011	2012	755 Bhp/1800 rpm
EG-5	Cummins QSK60-G6 NR2 2000 kW Diesel Engine Manufactured 2013	2014	2,919 Bhp/1800 rpm

Emission Limitations

Source ID#	Nitrogen Oxide (NO _x)		Carbon Monoxide (CO)		Volatile Organic Compounds		Sulfur Dioxide (SO ₂)		PM ₁₀	
	(lb/hr)	(ton/yr)	(lb/hr)	(ton/yr)	(lb/hr)	(ton/yr)	(lb/hr)	(ton/yr)	(lb/hr)	(ton/yr)
EG-3	38.6	9.65	3.67	0.92	1.42	0.35	0.90	0.23	1.03	0.26
EG-4	4.99	1.25	0.62	0.15	0.07	0.02	0.95	0.24	0.06	0.02
EG-5	38.6	9.65	3.67	0.92	1.42	0.35	0.90	0.23	1.03	0.26
TOTAL	82.19	20.55	7.96	1.99	2.91	0.72	2.75	0.70	2.12	0.54