




**Charleston Area  
Medical Center**

SAFETY OFFICE

3000 MacCorkle Ave. SE  
Charleston, WV 25304  
(304) 388-8208  
Fax: (304) 388-8891

May 11, 2016

Mr. Fred Durham  
West Virginia Department of Environmental Protection  
Division of Air Quality  
601 57<sup>th</sup> Street, SE  
Charleston, West Virginia 25304



**Re: CAMC Women & Children's Hospital Class I Administrative Update**  
800 Pennsylvania Avenue  
Charleston, Kanawha County, West Virginia  
Reg 13 Permit No.: R13-2452B

Dear Mr. Durham:

Charleston Area Medical Center (CAMC) is providing this Class I Administrative Update for CAMC Women & Children's Hospital to address minor changes needed to the current Regulation 13 Permit R13-2452B. The following revisions are requested:

**Revision 1** – Change facility name from CAMC – Women & Children's Division to CAMC Women & Children's Hospital throughout the permit.

**Revision 2** – In Section 1.0 Emission Units, Boiler #1 is listed as a natural gas/#2 fuel oil fired boiler and Boiler #2 as a natural gas fired boiler. Boiler #1 needs changed to a natural gas only fired boiler and Boiler #2 is a dual fuel, natural gas/#2 fuel oil fired boiler.

**Revision 3** – Remove ethylene oxide sterilizers #1, #2, and #3 from the permit as they are no longer present at the facility.

I trust the provided information will be sufficient to address the requested changes; however, if you have any questions or need any additional information, please do not hesitate to contact me at 304.388.8890.

Sincerely,

Nanci Keenan  
Safety Manager

WD BY WVDEP 11:08 AM MAY 26 2016