

West Virginia Department of Environmental Protection
Earl Ray Tomblin
Governor

Division of Air Quality

Randy C. Huffman
Cabinet Secretary

Class II General Permit G60-C Registration to Modify



for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to
construct the stationary sources of air pollutants identified herein in accordance
with all terms and conditions of General Permit G60-C.*

G60-C060A

Issued to:

Equitrans Limited Partnership
Burnsville #71
007-00006

A handwritten signature in blue ink, appearing to read "William F. Durham", written over a horizontal line.

William F. Durham
Director

Issued: August 12, 2015

This Class II General Permit Registration will supersede and replace G60-C060.

Facility Location: Burnsville, Braxton County, West Virginia
Mailing Address: PO Box 191
Burnsville, WV 26335
Facility Description: Natural Gas Compressor Station
SIC Codes: 4922
UTM Coordinates: 529.40 km Easting • 4,301.40 km Northing • Zone 17
Registration Type: Modification
Description of Change: Installation and operation of one (1) 302-bhp compressor engine.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class II General Permit G60-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class II General Permit G60-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition Internal
Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal
Combustion Engines (40CFR60 Subpart JJJJ)

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity
G-002A	Doosan - D111TIC	2015	302 bhp

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide		Volatile Organic Compounds	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
G-002A	0.02	0.01	0.18	0.05	0.17	0.05