



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street, S.E.  
Charleston, WV 25304

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
www.dep.wv.gov

June 15, 2016

Meaghan E. Atkinson  
Manager, Environmental Programs & Sustainability  
CSX Transportation  
500 Water Street – J275  
Jacksonville, FL 32202

Re: Permit Applicability Determination  
Barboursville Bridge Shop  
Cabell County, WV  
Determination No. PD16-037  
Plant ID No. 011-00065

Dear Ms. Atkinson:

It has been determined that a permit will not be required under 45CSR13 for the proposed replacement of the existing metal roll down door on the abrasive blasting booth with Geoscreen material at the above referenced facility. This determination is based on information included with your Permit Determination Form (PDF) received on May 24, 2016, which indicates that the increase in emissions will not exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility, may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer