



**west virginia department of environmental protection**

Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone: (304) 926-0475 • FAX: (304) 926-0479

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

March 25, 2016

CERTIFIED MAIL  
91 7199 9991 7035 6665 8820

DeRonica Lamb  
P.O. Box 5095, Room 4W200M  
San Ramon, CA 94583

Re: DirecTV Customer Services, Inc.  
Huntington Call Center  
Huntington, Cabell County, WV  
General Permit Registration No.: G60-C086  
Plant ID No.: 011-00217

Dear Mr. Lamb:

Your application for a permit as required by Section 5 of 45CSR13 - "Permits for Construction, Modification, Relocation and Operation of Stationary Sources of Air Pollutants, Notification Requirements, Temporary Permit, General Permit, and Procedures for Evaluation" has been approved. The enclosed general permit registration (G60-C086) is hereby issued pursuant to Subsection 5.7 of 45CSR13. Please be aware of the notification requirements in the permit which pertain to commencement of construction, modification, or relocation activities; startup of operations; and suspension of operations.


The source is not subject to 45CSR30.

In accordance with 45CSR22 - Air Quality Management Fee Program, enclosed with this permit is an Application for a Certificate to Operate (CTO), from the date of initial startup through the following June 30. Said application and the appropriate fee shall be submitted to this office no later than 30 days prior to the date of initial startup. For any startup date other than July 1, the permittee shall pay a fee or prorated fee in accordance with the Section 4.5 of 45CSR22. A copy of this schedule may be found on the reverse side of the Application for a Certificate to Operate (CTO).

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [ §§22B-1-1 et seq. ], Chapter 22B of the Code of West Virginia. West Virginia Code §§22-5-14.

Should you have any questions or comments, please contact me at (304) 926-0499, extension 1257.

Sincerely,

A handwritten signature in blue ink that reads "John Legg". The signature is written in a cursive style with a large, looping "J" and "L".

John Legg  
Permit Writer

Enclosures

cc: Brent Fitzgerald, Trinity Consultants

*West Virginia Department of Environmental Protection*  
Earl Ray Tomblin  
Governor

*Division of Air Quality*

Randy C. Huffman  
Cabinet Secretary

## Class II General Permit G60-C Registration to Construct



for the  
Prevention and Control of Air Pollution in regard to the  
Construction, Modification, Relocation, Administrative Update and  
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to  
construct the stationary sources of air pollutants identified herein in accordance  
with all terms and conditions of General Permit G60-C.*

**G60-C086**

Issued to:  
**DirectTV Customer Services, Inc.**  
Huntington Call Center  
Huntington, Cabell County, WV  
011-00217

A handwritten signature in blue ink, appearing to read "William F. Durham", written over a horizontal line.

*William F. Durham*  
Director

*Issued: March 25, 2016*

This Class II General Permit Registration does not supercede or replace another G60-C registration.

Facility Location: 2203 5<sup>th</sup> Street Road, Huntington, Cabell County, West Virginia  
Mailing Address: P.O. Box 5095, Room 4W200M, San Ramon, CA 94583  
Facility Description: Telephone Call Center  
SIC Code: 7389 – Business Services, Not Elsewhere Classified  
NAICS Code: 561420 – Telephone Call Centers  
UTM Coordinates: 372.70 km Easting • 4,249.93 km Northing • Zone 17S  
Lat/Long Coordinates: Latitude: 38.389° Longitude: -82.458°  
Registration Type: Construction  
Description of Change: Construction/installation of one (1), diesel-fueled 2,206 bhp (1,645 kW) Caterpillar 3512C engine with a 1,500 kW generator. The unit was purchased and installed new in 2011. The generator set is located outside the call center building on the south end of the site, and is equipped with a 2,600 gallon diesel-fuel storage tank. The generator is EPA Tier 2 certified. The generator will be used to supply power during an emergency and will be operated a maximum of 500 hr/yr.

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [ §§ 22B-1-1 et seq. ], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is not subject to 45CSR30.*

---

