



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.wvdep.org

February 25 2016

CERTIFIED MAIL
91 7199 9991 7034 1379 8297

Diana Charletta
Sr. Vice President - Midstream Operations
Route 4, Box 640
Weston, WV 26452

RE: Approved Registration G60-C085
Equitrans, L.P.
Copley Run Compressor Station
Plant ID No. 041-00009

Dear Ms. Charletta :

The Director has determined that the submitted Registration Application and proposed construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G60-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.6.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.
Engineer

Enclosures: General Permit Registration G60-C085
General Permit G60-C

Class II General Permit G60-C Registration to Construct



for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to
construct the stationary sources of air pollutants identified herein in accordance
with all terms and conditions of General Permit G60-C.*

G60-C085

Issued to:
Equitrans, L.P.
Copley Run Compressor Station
041-00009

A blue ink signature of William F. Durham, written over a horizontal line.

William F. Durham
Director

Issued: February 25, 2016

Effective: February 25, 2016

Facility Location: Weston, Lewis County, West Virginia
Mailing Address: Route 4, Box 640, Weston, WV 26452
Facility Description: Emergency Generator
SIC Codes: 4922
UTM Coordinates: 541.390 km Easting • 4314.773 km Northing • Zone 17
Registration Type: Construction
Description of Change: Installation of one natural gas-fired generator to be used in emergency situations.

Subject to 40CFR60 Subpart IIII? No
Subject to 40CFR60 Subpart JJJJ? Yes, Certified? Yes

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class II General Permit G60-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class II General Permit G60-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
G-003	Kohler 150REZGC – PSI Industrial, 8.8L	2015	193 bhp/1800

Reciprocating Internal Combustion Engines (R.I.C.E.) Information

Emission Unit ID	Subject to 40CFR60 Subpart IIII?	Subject to 40CFR60 Subpart JJJJ?	Subject to Sections 5.1.4/5.2.1 (Catalytic Reduction Device)
G-003	No	Yes	No

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide		Volatile Organic Compounds	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	4.24	1.06	8.49	2.12	2.12	0.53