



west virginia department of environmental protection

Division of Air Quality
601 57th Street, S.E.
Charleston, WV 25304

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

March 3, 2016

Mr. Lynn Martin
President
WKLC, Inc.
100 Kanawha Terrace
Saint Albans, WV 25177

Re: WKLC-FM Radio Tower Facility
Putnam County, WV
Facility ID No. 079-00190
Determination No. PD16-020

Dear Mr. Martin:

It has been determined that a permit will not be required for your proposed installation and operation of a 324 hp diesel fired emergency generator set at the above referenced facility. This determination is based on information included with your General Permit G65-C Registration Application received on February 17, 2016, which indicates that the increase in emissions will not exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility, may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

William T. Rothwell II, P.E.
Engineer