

West Virginia Department of Environmental Protection
Earl Ray Tomblin Governor Division of Air Quality Randy C. Huffman Cabinet Secretary

Class I General Permit G65-C Registration to Construct



for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to
construct the stationary sources of air pollutants identified herein in accordance
with all terms and conditions of General Permit G65-C.*

G65-C546

Issued to:
Greater Marion Public Service District
Idamay, Marion County
049-00184

A blue ink signature of William F. Durham, written over a horizontal line.

William F. Durham
Director

Effective: March 04, 2015

This Class I General Permit Registration does not affect any other 45CSR13 permits.

Facility Location: Idamay, Marion County, West Virginia
Mailing Address: 44 Aberdeen Drive, Worthington, WV 26591
Facility Description: Emergency Generator
SIC Codes: 4952
UTM Coordinates: 563.47 km Easting • 4371.41 km Northing • Zone 17
Registration Type: Construction
Description of Change: Installation of an emergency generator used during power outages.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

Unless otherwise stated WVDEP DAQ did not determine whether the permittee is subject to an area source air toxics standard requiring Generally Achievable Control Technology (GACT) promulgated after January 1, 2007 pursuant to 40 CFR 63, including the area source air toxics provisions of 40 CFR 63, Subpart HH and 40 CFR 63, Subpart ZZZZ.

All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

