west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone: (304) 926-0475 • FAX: (304) 926-0479

Jim Justice, Governor
Austin Caperton, Cabinet Secretary
www.dep.wv.gov

May 12, 2017

Mark Smith
Board Chairman
Pocahontas County Public Service District
HC 63 Box 122
Frank, West Virgina 24920

Re: Pocahontas County Public Service District
Snowshoe Village Pump Station
Permit No. G65-C565
Plant ID No. 075-00037

Dear Mr. Smith:

Your application for a permit as required by Section 5 of 45CSR13 - "Permits for Construction, Modification, Relocation and Operation of Stationary Sources of Air Pollutants, Notification Requirements, Temporary Permit, General Permit, and Procedures for Evaluation" has been approved. The enclosed permit G65-C565 is hereby issued pursuant to Subsection 5.7 of 45CSR13. Please be aware of the notification requirements in the permit which pertain to commencement of construction, modification, or relocation activities; startup of operations; and suspension of operations.

The source is not subject to 45CSR30.

In accordance with 45CSR22 - Air Quality Management Fee Program, the permittee shall not operate nor cause to operate the permitted facility or other associated facilities on the same or contiguous sites comprising the plant without first obtaining and having in current effect a Certificate to Operate (CTO). Such Certificate to Operate (CTO) shall be renewed annually, shall be maintained on the premises for which the Certificate has been issued, and shall be made immediately available for inspection by the Secretary or his/her duly authorized representative.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §§22-5-14.

Should you have any questions or comments, please contact me at (304) 926-0499, extension 1246.

Sincerely,

Renu M. Chakrabarty

Renu M. Chakrabarty, PE
Air Toxics Coordinator

Enclosures

Mr. Mark Smith: wvctrack@yahoo.com
Mr. Nick Josties, Waste Water Management, Inc., nick.josties@wwmi.net

West Virginia Department of Environmental Protection

Jim Justice
Governor

Division of Air Quality

Austin Caperton
Cabinet Secretary

Class I General Permit
G65-C Registration to Construct

for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

The permittee identified at the facility listed below is authorized to construct the stationary sources of air pollutants identified herein in accordance with all terms and conditions of General Permit G65-C.

G65-C565

Issued to:
Pocahontas County Public Service District
Snowshoe Village Pump Station
075-00037

William F. Durham
Director

Issued: May 12, 2017

Facility Location: Slatyfork, Pocahontas County, County, West Virginia
Mailing Address: HC 63 Box 122, Frank, West Virginia 24920
Facility Description: New sewage pumping station
SIC Codes: 4952
UTM Coordinates: 587.01603 km Easting • 4253.74836 km Northing • Zone 17
Registration Type: Construction
Description of Change: This is a new sewage pumping station to convey sewage from the existing collection system to a new wastewater treatment plant.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class I General Permit G65-C apply to the registrant:

Section 5	Reciprocating Internal Combustion Engines (R.I.C.E.)	×
Section 6	Tanks	☐
Section 7	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)	×
Section 8	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)	☐

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-10	Cummins 4BT3.3-G5 NR3 4SLB RICE, 3.3 liter displacement	2017	69 bhp

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide		Volatile Organic Compounds	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EG-10	0.41	0.1	0.7	0.18	0.015	0.0038