



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone (304) 926-0475 • FAX: (304) 926-0479

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

ENGINEERING EVALUATION / FACT SHEET

BACKGROUND INFORMATION

Application No.: R13-3201A
Plant ID No.: 017-00114
Applicant: Antero Midstream LLC (Antero)
Facility Name: Nichols Compressor Station
Location: Greenwood, Doddridge County
NAICS Code: 221210 (Natural Gas Distribution)
Application Type: Modification
Received Date: August 12, 2015
Engineer Assigned: Jerry Williams, P.E.
Fee Amount: \$2,000.00
Date Received: August 12, 2015
Complete Date: September 8, 2015
Due Date: December 7, 2015
Applicant Ad Date: August 17, 2015
Newspaper: *Herald Record*
UTM's: Easting: 511.253 km Northing: 4,349.253 km Zone: 17
Latitude: 39.292576
Longitude: -80.869506
Description: Addition of a catalytic heater and the operating conditions of NSCR catalysts, emission calculations for storage tanks and truck loading emissions, fugitive dust emissions for haul road traffic, and operating hours of the microturbine generators have been updated. A fuel usage limitation will be placed on the engines. This permitting action will constitute a synthetic minor for nitrogen oxides and carbon monoxide emissions.

DESCRIPTION OF PROCESS

Permit R13-3201 was issued to Antero for this facility on December 29, 2014. This facility began operation on April 10, 2015. This proposed permitting action results in one (1) 0.024 MMBTU/hr catalytic heater being added. Otherwise, the modification results only in a change in operating conditions.

The following process description was taken from Permit Application R13-3201A:

The Nichols Compressor Station is located in Doddridge County, West Virginia. Gas from surrounding pipelines enters the facility through one (1) receiver and associated slug catcher. From there, the gas is metered and routed through a scrubber and filter separator. Any produced liquids from the scrubber or separator are sent to the 400 barrel settling tank (T03). Gas from the filter separator is sent to one (1) of eleven (11) 1,680 horsepower (HP) Waukesha compressor engines (CE-01 through CE-11). The eleven (11) compressor engines are controlled with non-selective catalytic reduction (NSCR) catalysts and air-fuel ratio controllers (C-02 through C-12). Produced fluids are routed to the settling tank and gas going to one of the two (2) tri-ethylene glycol (TEG) dehydrators.

Each TEG dehydrator (RSV-1 and RSV-2) contains a flash gas tank and 1.5 million British Thermal Units per hour (MMBtu/hr) reboiler. Each dehydrator has a design rate of 60 million standard cubic feet per day (MMscf/day). Within the dehydrator unit, vent gas from the flash gas tank is routed to the reboiler (RBV-1 and RBV-2) and used as fuel. Emissions from each reboiler are routed to the atmosphere. The dehydrator still vents (RSV-1 and RSV-2) are controlled by a combustor with at least 98% control efficiency (C-01). Produced fluids from the dehydrator are routed to the settling tank. The dry gas from the dehydration process is either routed to a fuel gas scrubber, metered, and routed to the compressors as fuel gas or metered and sent to plant discharge.

All produced fluids enter one (1) 400 barrel (bbl) settling tank (T03) where the fluids settle out as either condensate or produced water. The produced water goes to two (2) 400 bbl produced water tanks (T01 and T02) and the condensate goes to two (2) 400 bbl condensate tanks (T04 and T05). Flashing only occurs at the settling tank as the fluids stabilize in the settling tank before going to the other storage tanks. All five (5) tanks are connected to a vapor recovery unit (C-13) where tank vapors are collected and recycled back into the gas system right before the initial filter scrubber. There is a second vapor recovery unit (C-14) that is used as a back-up control for the storage tanks. The produced fluids are trucked out via tanker trucks as needed (EPLOR). The production is 151 bbls per day of condensate and 45 bbls per day of produced water.

Two (2) natural gas microturbine generators, each rated at 200 kWe supply power to the facility (GEN1 – GEN2). A small 24,000 Btu/hr catalytic heater (CATHT-1) is used to heat the fuel to power the generators. Fugitive emissions from component leaks, traffic on unpaved roads, and emissions from venting or blowdown events also occur.

There will also be nine (9) small storage tanks onsite. A list of the tanks and their capacity is in the table below:

Tank ID	Storage Tank Description	Storage Tank Capacity (gal)
TK-9440	Compressor Skid Settling Tank	1,000
TK-9410	Bulk TEG Storage Tank	1,000
TK-9430	Bulk Lube Oil Storage Tank	1,000
TK-9330	Waste Oil Storage Tank	1,000
TK-9420	Bulk Coolant Storage Tank	1,000
TK-9300	Compressor Skid Oily Water Tank	1,000
TK-9310	Sump Collection Tank	1,000
TK-9320	Jacket Water Storage Tank	1,000
TK-9400	Compressor Waste Oil Tank	4,200

SITE INSPECTION

A site inspection was conducted on August 7, 2014 by Doug Hammell of the DAQ Enforcement Section. According to Mr. Hammell, the site is appropriate for the facility.

Directions as given in the permit application are as follows:

US-50 towards Greenwood. Head northwest on CR-50/30 (Sunnyside Road) for 0.3 miles. Make the first right and head east on CR-36 (Duckworth Road) for 1.0 mile. Turn left and head north on CR-26 (Long Run Road) for 1.1 miles. Turn left onto access road and travel 0.3 miles to the facility.



ESTIMATE OF EMISSIONS BY REVIEWING ENGINEER

Emissions associated with this facility consist of the equipment listed in the following table and fugitive emissions. Fugitive emissions for the facility are based on calculation methodologies presented in EPA Protocol for Equipment Leak Emission Estimates. The following table indicates which methodology was used in the emissions determination:

Emission Unit ID#	Process Equipment	Calculation Methodology
CE-01 – CE-11	1,680 hp Waukesha 7044 GSI Reciprocating Internal Combustion Engine (RICE) w/ NSCR	Manufacturer's Data, EPA AP-42 Emission Factors
GEN1, GEN2	200 kW Capstone C200 NG Microturbine Generators	Manufacturer's Data, EPA AP-42 Emission Factors
CATHT1	0.024 MMBTU/hr Catalytic Heater	EPA AP-42 Emission Factors
RSV-1, RSV-2	60 mmscfd TEG Dehydrator Still Vent w/ Condenser/Recycle and Flare	GRI-GlyCalc 4.0
RBV-1, RBV-2	1.5 MMBtu/hr TEG Dehydrator Reboiler	EPA AP-42 Emission Factors
T01, T02	400 bbl (16,800 gal) Produced Water Storage Tanks	EPA Tanks 4.09d
T03	400 bbl (16,800 gal) Produced Water/Condensate Settling Tank	EPA Tanks 4.09d and ProMax Simulation (Flashing)
T04, T05	400 bbl (16,800 gal) Condensate Storage Tanks	EPA Tanks 4.09d
TK-9440	1,000 gal Compressor Skid Settling Storage Tank	Negligible
TK-9410	1,000 gal Bulk TEG Storage Tank	Negligible
TK-9430	1,000 gal Bulk Lube Oil Storage Tank	Negligible
TK-9330	1,000 gal Waste Oil Storage Tank	Negligible
TK-9420	1,000 gal Bulk Coolant Storage Tank	Negligible
TK-9300	1,000 gal Compressor Skid Oily Water Storage Tank	Negligible
TK-9310	1,000 gal Sump Collection Storage Tank	Negligible
TK-9320	1,000 gal Jacket Water Storage Tank	Negligible
TK-9400	4,200 gal Compressor Waste Oil Storage Tank	Negligible
EPLOR	71,395 bbl/yr (2,998,590 gal/yr) Product Loadout Rack	EPA AP-42 Emission Factors
C-13	Vapor Recovery Unit #1	Electric Driven
C-14	Vapor Recovery Unit #2	Electric Driven
C-01	4.8 MMBTU/hr Flare Control Device	EPA AP-42 Emission Factors

The following table indicates the control device efficiencies that are required for this facility:

Emission Unit	Pollutant	Control Device	Control Efficiency
1,680 hp Waukesha 7044 GSI RICE w/ NSCR (CE-01 – CE-11)	Nitrogen Oxides	NSCR	96 %
	Carbon Monoxide		96 %
	Volatile Organic Compounds		50 %
	Formaldehyde		76 %
	Methane		70 %
60 mmscfd TEG Dehydrator Still Vents (RBV-1, RBV-2)	Volatile Organic Compounds	Flare	98 %
	Hazardous Air Pollutants		98 %
60 mmscfd TEG Dehydrator Flash Tanks	Volatile Organic Compounds	Recycled Reboiler/ Condenser	95 %
	Hazardous Air Pollutants		95 %
Product Tanks (T01 – T05)	Volatile Organic Compounds	Vapor Recovery Units	98 %
	Hazardous Air Pollutants		98 %

The total facility PTE for the Nichols Compressor Station is shown in the following table:

Pollutant	R13-3201 PTE (tons/year)	R13-3201A PTE (tons/year)	PTE Change (tons/year)
Nitrogen Oxides	28.41	90.80	62.39
Carbon Monoxide	57.46	93.28	35.82
Volatile Organic Compounds	96.11	86.12	-9.99
Particulate Matter-10	6.47	13.25	6.78
Sulfur Dioxide	0.39	0.44	0.05
Formaldehyde	1.79	1.94	0.15
Total HAPs	12.39	9.74	-2.65
Carbon Dioxide Equivalent	88,692	93,874	5,182

Maximum detailed controlled point source emissions were calculated by Antero and checked for accuracy by the writer and are summarized in the table on the next page.

Antero Midstream LLC – Nichols Compressor Station (R13-3201A)

Emission Point ID#	Source	NO _x		CO		VOC		PM-10		SO ₂		Formaldehyde		Total HAPs		CO _{2e} ton/year
		lb/hr	ton/year	lb/hr	ton/year	lb/hr	ton/year	lb/hr	ton/year	lb/hr	ton/year	lb/hr	ton/year	lb/hr	ton/year	
15E	Compressor Engine #1	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
16E	Compressor Engine #2	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
17E	Compressor Engine #3	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
18E	Compressor Engine #4	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
19E	Compressor Engine #5	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
20E	Compressor Engine #6	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
21E	Compressor Engine #7	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
22E	Compressor Engine #8	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
23E	Compressor Engine #9	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
24E	Compressor Engine #10	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
25E	Compressor Engine #11	2.01	7.93	1.90	7.46	0.74	2.92	0.27	1.06	<0.01	0.03	0.04	0.17	0.13	0.51	7,841
26E, 27E	Microturbine Generators	0.20	0.84	0.52	2.32	0.04	0.22	0.03	0.14	0.02	0.07	<0.01	0.02	<0.01	0.02	2,332
29E	Dehydrator Still Vent #1 + Flash Tank	0.00	0.00	0.00	0.00	1.12	4.89	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.21	121
28E	Dehydrator Reboiler	0.15	0.64	0.12	0.54	0.01	0.04	0.01	0.05	<0.01	<0.01	<0.01	<0.01	<0.01	0.01	771
31E	Dehydrator Still Vent #2 + Flash Tank	0.00	0.00	0.00	0.00	1.12	4.89	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.21	121
30E	Dehydrator Reboiler	0.15	0.64	0.12	0.54	0.01	0.04	0.01	0.05	<0.01	<0.01	<0.01	<0.01	<0.01	0.01	771
1E	Flare Combustion	0.33	1.44	1.78	7.79	1.91	8.36	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	0.34	1.51	2,663
34E	Settling Storage Tank	0.00	0.00	0.00	0.00	1.83	8.01	0.00	0.00	0.00	0.00	0.00	0.00	0.14	0.64	23
35E, 36E	Condensate Storage Tanks	0.00	0.00	0.00	0.00	0.05	0.22	0.00	0.00	0.00	0.00	0.00	0.00	<0.01	<0.01	1
32E, 33E	Produced Water Storage Tanks	0.00	0.00	0.00	0.00	<0.01	<0.01	0.00	0.00	0.00	0.00	0.00	0.00	<0.01	<0.01	<1
37E	Product Loadout Rack	0.00	0.00	0.00	0.00	57.54	7.87	0.00	0.00	0.00	0.00	0.00	0.00	4.53	0.62	21
47E	Catalytic Heater	<0.01	0.01	<0.01	0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	12
Total Point Source		22.98	90.80	23.41	93.28	71.75	66.67	3.03	11.95	0.11	0.44	0.49	1.94	6.56	8.86	93,091
Fugitive Component Leaks		0.00	0.00	0.00	0.00	2.41	10.57	0.00	0.00	0.00	0.00	0.00	0.00	0.11	0.48	142
Fugitive Venting		0.00	0.00	0.00	0.00	NA	8.88	0.00	0.00	0.00	0.00	0.00	0.00	NA	0.40	642
Fugitive Dust		0.00	0.00	0.00	0.00	0.00	0.00	0.30	1.30	0.00	0.00	0.00	0.00	0.00	0.00	0
Total Fugitive		0.00	0.00	0.00	0.00	2.41	19.45	0.30	1.30	0.00	0.00	0.00	0.00	0.11	0.88	783
Total Site-wide		22.98	90.80	23.41	93.28	74.16	86.12	3.33	13.25	0.11	0.44	0.49	1.94	6.67	9.74	93,874

REGULATORY APPLICABILITY

The following rules apply to the facility:

45CSR2 (Particulate Air Pollution from Combustion of Fuel in Indirect Heat Exchangers)

The purpose of 45CSR2 is to establish emission limitations for smoke and particulate matter which are discharged from fuel burning units. 45CSR2 states that any fuel burning unit that has a heat input under ten (10) million B.T.U.'s per hour is exempt from sections 4 (weight emission standard), 5 (control of fugitive particulate matter), 6 (registration), 8 (testing, monitoring, recordkeeping, reporting) and 9 (startups, shutdowns, malfunctions). However, failure to attain acceptable air quality in parts of some urban areas may require the mandatory control of these sources at a later date.

The individual heat input of the reboilers (RBV-1, RBV-2) are below 10 MMBTU/hr. Therefore, these units are exempt from the aforementioned sections of 45CSR2.

Antero would also be subject to the opacity requirements in 45CSR2, which is 10% opacity based on a six minute block average.

45CSR6 (To Prevent and Control Air Pollution from the Combustion of Refuse)

The purpose of this rule is to prevent and control air pollution from combustion of refuse.

Antero has one (1) flare at the facility. The flare is subject to section 4, emission standards for incinerators. The flare has an allowable emission rate of 161 pounds of particulate matter per hour (assuming a natural gas density of 0.044 lb/ft³). The flare has negligible hourly particulate matter emissions. Therefore, the facility's flare should demonstrate compliance with this section. The facility will demonstrate compliance by maintaining records of the amount of natural gas consumed by the flare and the hours of operation. The facility will also monitor the flame of the flare and record any malfunctions that may cause no flame to be present during operation.

45CSR10 (To Prevent and Control Air Pollution from the Emissions of Sulfur Oxides)

The purpose of 45CSR10 is to establish emission limitations for sulfur dioxide which are discharged from fuel burning units. 45CSR10 states that any fuel burning unit that has a heat input under ten (10) million B.T.U.'s per hour is exempt from sections 3 (weight emission standard), 6 (registration), 7 (permits), and 8 (testing, monitoring, recordkeeping, reporting). However, failure to attain acceptable air quality in parts of some urban areas may require the mandatory control of these sources at a later date.

The individual heat input of the reboilers (RBV-1, RBV-2) are below 10 MMBTU/hr. Therefore, these units are exempt from the aforementioned sections of 45CSR10.

45CSR13 (Permits for Construction, Modification, Relocation and Operation of Stationary Sources of Air Pollutants, Notification Requirements, Administrative Updates, Temporary Permits, General Permits, and Procedures for Evaluation)

A 45CSR13 modification permit applies to this source due to the fact that Antero exceeds the regulatory emission threshold for criteria pollutants of 6 lb/hr and 10 ton/year of nitrogen oxides and carbon monoxide.

In addition, because a limitation was placed on the maximum annual fuel consumption of engines (CE-01- CE-11) to remain below major source thresholds for nitrogen oxides and carbon monoxide, Antero is subject to Notice Level C (45CSR13 Section 8.5) and will be required to publish a commercial display ad (45CSR13 Section 8.4.a) and post a visible sign at their facility (45CSR13 Section 8.5.a).

Antero paid the appropriate application fee and published the required legal advertisement for a construction permit application.

45CSR16 (Standards of Performance for New Stationary Sources Pursuant to 40 CFR Part 60)

45CSR16 applies to this source by reference of 40CFR60, Subparts JJJJ and OOOO. These requirements are discussed under that rule below.

45CSR22 (Air Quality Management Fee Program)

Antero is not subject to 45CSR30. The Nichols Compressor Station is subject to 40CFR60 Subparts JJJJ and OOOO, however they are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided they are not required to obtain a permit for a reason other than their status as an area source.

Antero is required to pay the appropriate annual fees and keep their Certificate to Operate current.

40CFR60 Subpart JJJJ (Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (SI ICE))

40CFR60 Subpart JJJJ establishes emission standards for applicable SI ICE.

The 1,680 hp Waukesha 7044 GSI RICEs (CE01 – CE-11) were manufactured after the July 1, 2007 date for engines with a maximum rated power capacity greater than or equal to 500 hp.

The 1,680 hp Waukesha 7044 GSI RICEs (CE-01 – CE-11) will be subject to the following emission limits: NO_x – 1.0 g/hp-hr (3.70 lb/hr); CO – 2.0 g/hp-hr (7.41 lb/hr); and VOC – 0.7 g/hp-hr (2.59 lb/hr). Based on the manufacturer's specifications for these engines, the emission standards will be met.

The 1,680 hp Waukesha 7044 GSI RICEs (CE-01 – CE-11) are not certified by the manufacturer to meet the emission standards listed in 40CFR60 Subpart JJJJ. Therefore,

Antero will be required to conduct an initial performance test and conduct subsequent performance testing every 8,760 hours or three (3) years, whichever comes first, to demonstrate compliance.

40CFR60 Subpart OOOO (Standards of Performance for Crude Oil and Natural Gas Production, Transmission and Distribution)

EPA published in the Federal Register new source performance standards (NSPS) and air toxics rules for the oil and gas sector on August 16, 2012. 40CFR60 Subpart OOOO establishes emission standards and compliance schedules for the control of volatile organic compounds (VOC) and sulfur dioxide (SO₂) emissions from affected facilities that commence construction, modification or reconstruction after August 23, 2011. The following affected sources which commence construction, modification or reconstruction after August 23, 2011 are subject to the applicable provisions of this subpart: Each gas well affected facility, which is a single natural gas well.

There are no gas wells at this facility. Therefore, all requirements regarding gas well affected facilities under 40 CFR 60 Subpart OOOO would not apply.

- a. Each centrifugal compressor affected facility, which is a single centrifugal compressor using wet seals that is located between the wellhead and the point of custody transfer to the natural gas transmission and storage segment. For the purposes of this subpart, your centrifugal compressor is considered to have commenced construction on the date the compressor is installed (excluding relocation) at the facility. A centrifugal compressor located at a well site, or an adjacent well site and servicing more than one well site, is not an affected facility under this subpart.

There are no centrifugal compressors at the Nichols Compressor Station. Therefore, all requirements regarding centrifugal compressors under 40 CFR 60 Subpart OOOO would not apply.

- b. Each reciprocating compressor affected facility, which is a single reciprocating compressor located between the wellhead and the point of custody transfer to the natural gas transmission and storage segment. For the purposes of this subpart, your reciprocating compressor is considered to have commenced construction on the date the compressor is installed (excluding relocation) at the facility. A reciprocating compressor located at a well site, or an adjacent well site and servicing more than one well site, is not an affected facility under this subpart.

There are reciprocating internal combustion engines located at the Nichols Compressor Station that were constructed after August 23, 2011. Therefore, the requirements regarding reciprocating compressors under 40 CFR 60 Subpart OOOO will apply. Antero will be required to perform the following:

- Replace the reciprocating compressor rod packing at least every 26,000 hours of operation or 36 months or installation of a rod packing emissions collection system.

- Demonstrate initial compliance by continuously monitoring the number of hours of operation or track the number of months since the last rod packing replacement.
- Submit the appropriate start up notifications.
- Submit the initial annual report for the reciprocating compressors.
- Maintain records of hours of operation since last rod packing replacement, records of the date and time of each rod packing replacement, and records of deviations in cases where the reciprocating compressor was not operated in compliance.

c. Pneumatic Controllers

- Each pneumatic controller affected facility, which is a single continuous bleed natural gas-driven pneumatic controller operating at a natural gas bleed rate greater than 6 scfh which commenced construction after August 23, 2011, and is located between the wellhead and the point of custody transfer to the natural gas transmission and storage segment and not located at a natural gas processing plant.
- Each pneumatic controller affected facility, which is a single continuous bleed natural gas-driven pneumatic controller which commenced construction after August 23, 2011, and is located at a natural gas processing plant.

All pneumatic controllers at the facility will be air driven. Therefore, there are no applicable pneumatic controllers which commenced construction after August 23, 2011. Therefore, all requirements regarding pneumatic controllers under 40 CFR 60 Subpart OOOO would not apply.

- d. Each storage vessel affected facility, which is a single storage vessel, located in the oil and natural gas production segment, natural gas processing segment or natural gas transmission and storage segment.

40CFR60 Subpart OOOO defines a storage vessel as a unit that is constructed primarily of non-earthen materials (such as wood, concrete, steel, fiberglass, or plastic) which provides structural support and is designed to contain an accumulation of liquids or other materials. The following are not considered storage vessels:

- Vessels that are skid-mounted or permanently attached to something that is mobile (such as trucks, railcars, barges or ships), and are intended to be located at a site for less than 180 consecutive days. If the source does not keep or are not able to produce records, as required by §60.5420(c)(5)(iv), showing that the vessel has been located at a site for less than 180

consecutive days, the vessel described herein is considered to be a storage vessel since the original vessel was first located at the site.

- Process vessels such as surge control vessels, bottoms receivers or knockout vessels.
- Pressure vessels designed to operate in excess of 204.9 kilopascals and without emissions to the atmosphere.

This rule requires that the permittee determine the VOC emission rate for each storage vessel affected facility utilizing a generally accepted model or calculation methodology within 30 days of startup, and minimize emissions to the extent practicable during the 30 day period using good engineering practices. For each storage vessel affected facility that emits more than 6 tpy of VOC, the permittee must reduce VOC emissions by 95% or greater within 60 days of startup. The compliance date for applicable storage vessels is October 15, 2013.

The storage vessels located at the Nichols Compressor Station are controlled by a VRU which will reduce the potential to emit to less than 6 tpy of VOC. Therefore, Antero is not required by this section to further reduce VOC emissions by 95%. Antero is claiming a control efficiency of 98% for the VRU. In able to claim a control efficiency greater than 95%, Antero is required to meet additional design/function requirements. Antero will be required to perform three (3) of the following additional requirements:

- *Additional sensing equipment.*
- *Properly designed bypass system.*
- *Appropriate gas blanket.*
- *A compressor that is suitable and has the ability to vary the drive speed.*

- e. The group of all equipment, except compressors, within a process unit is an affected facility.
- Addition or replacement of equipment for the purpose of process improvement that is accomplished without a capital expenditure shall not by itself be considered a modification under this subpart.
 - Equipment associated with a compressor station, dehydration unit, sweetening unit, underground storage vessel, field gas gathering system, or liquefied natural gas unit is covered by §§60.5400, 60.5401, 60.5402, 60.5421 and 60.5422 of this subpart if it is located at an onshore natural gas processing plant. Equipment not located at the onshore natural gas processing plant site is exempt from the provisions of §§60.5400, 60.5401, 60.5402, 60.5421 and 60.5422 of this subpart.
 - The equipment within a process unit of an affected facility located at onshore natural gas processing plants and described in paragraph (f) of

this section are exempt from this subpart if they are subject to and controlled according to subparts VVa, GGG or GGGa of this part.

The Nichols Compressor Station is not a natural gas processing plant. Therefore, Leak Detection and Repair (LDAR) requirements for onshore natural gas processing plants would not apply.

- f. Sweetening units located at onshore natural gas processing plants that process natural gas produced from either onshore or offshore wells.
- Each sweetening unit that processes natural gas is an affected facility; and
 - Each sweetening unit that processes natural gas followed by a sulfur recovery unit is an affected facility.
 - Facilities that have a design capacity less than 2 long tons per day (LT/D) of hydrogen sulfide (H₂S) in the acid gas (expressed as sulfur) are required to comply with recordkeeping and reporting requirements specified in §60.5423(c) but are not required to comply with §§60.5405 through 60.5407 and paragraphs 60.5410(g) and 60.5415(g) of this subpart.
 - Sweetening facilities producing acid gas that is completely reinjected into oil-or-gas-bearing geologic strata or that is otherwise not released to the atmosphere are not subject to §§60.5405 through 60.5407, 60.5410(g), 60.5415(g), and 60.5423 of this subpart.

There are no sweetening units at the Nichols Compressor Station. Therefore, all requirements regarding sweetening units under 40 CFR 60 Subpart OOOO would not apply.

40CFR63 Subpart HH (National Emission Standards for Hazardous Air Pollutants for Oil and Natural Gas Production Facilities)

Subpart HH establishes national emission limitations and operating limitations for HAPs emitted from oil and natural gas production facilities located at major and area sources of HAP emissions. The glycol dehydration units at the Nichols Compressor Station are subject to the area source requirements for glycol dehydration units. However, because the facility is an area source of HAP emissions and the actual average benzene emissions from the glycol dehydration unit is below 0.90 megagram per year (1.0 tons/year) it is exempt from all requirements of Subpart HH except to maintain records of actual average flowrate of natural gas to demonstrate a continuous exemption status.

40CFR63 Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines)

Subpart ZZZZ establishes national emission limitations and operating limitations for HAPs emitted from stationary RICE located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations. The engines (CE-01 – CE-11) at the Nichols Compressor Station are subject to the area source requirements for non-emergency spark ignition engines.

The applicability requirements for new stationary RICEs located at an area source of HAPs, is the requirement to meet the standards of 40CFR60 Subpart JJJJ. These requirements were outlined above. The proposed engine meets these standards.

Because these engines are not certified by the manufacturer, Antero will be required to perform an initial performance test within 180 days from startup, and subsequent testing every 8,760 hours or 3 years, whichever comes first.

The following rules do not apply to the facility:

45CSR14 (Permits for Construction and Major Modification of Major Stationary Sources of Air Pollutants)

45CSR19 (Permits for Construction and Major Modification of Major Stationary Sources of Air Pollution which Cause or Contribute to Nonattainment)

The Nichols Compressor Station is located in Doddridge County, which is an unclassified county for all criteria pollutants, therefore the Nichols Compressor Station is not applicable to 45CSR19.

As shown in the following table, Antero is not a major source subject to 45CSR14 or 45CSR19 review. According to 45CSR14 Section 2.43.e, fugitive emissions are not included in the major source determination because it is not listed as one of the source categories in Table 1. Therefore, the fugitive emissions are not included in the PTE below.

Pollutant	PSD (45CSR14) Threshold (tpy)	NANSR (45CSR19) Threshold (tpy)	Nichols PTE (tpy)	45CSR14 or 45CSR19 Review Required?
Carbon Monoxide	250	NA	93.28	No
Nitrogen Oxides	250	NA	90.80	No
Sulfur Dioxide	250	NA	0.44	No
Particulate Matter 2.5	250	NA	11.95	No
Ozone (VOC)	250	NA	66.67	No

45CSR30 (Requirements for Operating Permits)

Antero is not subject to 45CSR30. The Nichols Compressor Station is subject to 40CFR60 Subparts JJJJ and OOOO, however they are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided they are not required to obtain a permit for a reason other than their status as an area source.

40CFR60 Subpart Kb (Standards of Performance for VOC Liquid Storage Vessels)

40CFR60 Subpart Kb does not apply to storage vessels with a capacity less than 75 cubic meters. The largest tanks that Antero has proposed to install are 63.60 cubic meters each. Therefore, Antero would not be subject to this rule.

40CFR60 Subpart KKK (Standards of Performance for Equipment Leaks of VOC from Onshore Natural Gas Processing Plants)

40CFR60 Subpart KKK applies to onshore natural gas processing plants that commenced construction after January 20, 1984, and on or Before August 23, 2011. The Nichols Compressor Station is not a natural gas processing facility, therefore, Antero is not subject to this rule.

40CFR60 Subpart KKKK (Standards of Performance for Stationary Combustion Turbines)

40CFR60 Subpart KKKK does not apply because there are no stationary combustion turbines at the facility with a heat input at peak load equal to or greater than 10 MMBTU/hr, based on the higher heating value of the fuel (§60.4305).

TOXICITY OF NON-CRITERIA REGULATED POLLUTANTS

The majority of non-criteria regulated pollutants fall under the definition of HAPs which, with some revision since, were 188 compounds identified under Section 112(b) of the Clean Air Act (CAA) as pollutants or groups of pollutants that EPA knows or suspects may cause cancer or other serious human health effects. The Nichols Compressor Station is classified as an area source of hazardous air pollutants. Listed below is a description of the primary hazardous air pollutants for this facility.

Acetaldehyde

Acetaldehyde is mainly used as an intermediate in the synthesis of other chemicals. It is common in the environment and may be formed in the body from the breakdown of ethanol. Acute (short-term) exposure to acetaldehyde results in effects including irritation of the eyes, skin, and respiratory tract. Symptoms of chronic (long-term) intoxication of acetaldehyde resemble those of alcoholism. Acetaldehyde is considered a probable human carcinogen (Group B2) based on human cancer studies and animal studies that have shown nasal tumors in rats and laryngeal tumors in hamsters.

Acrolein

Acrolein is primarily used as an intermediate in the synthesis of acrylic acid and as a biocide. It may be formed from the breakdown of certain pollutants in outdoor air or from the burning of organic matter including tobacco, or fuels such as gasoline or oil. It is toxic to humans following inhalation, oral or dermal exposures. Acute (short-term) inhalation exposure may result in upper respiratory tract irritation and congestion. No information is available on its reproductive, developmental, or carcinogenic effects in humans, and the existing animal cancer data are considered inadequate to make a determination that acrolein is carcinogenic to humans.

Benzene

Benzene is found in the air from emissions from burning coal and oil, gasoline service stations, and motor vehicle exhaust. Acute (short-term) inhalation exposure of humans to benzene may cause drowsiness, dizziness, headaches, as well as eye, skin, and respiratory tract irritation, and, at high levels, unconsciousness. Chronic (long-term) inhalation exposure has caused various disorders in the blood, including reduced numbers of red blood cells and aplastic anemia, in occupational settings. Reproductive effects have been reported for women exposed by inhalation to high levels, and adverse effects on the developing fetus have been observed in animal tests. Increased incidence of leukemia (cancer of the tissues that form white blood cells) have been observed in humans occupationally exposed to benzene. EPA has classified benzene as a Group A, human carcinogen

Formaldehyde

Formaldehyde is used mainly to produce resins used in particle board products and as an intermediate in the synthesis of other chemicals. Exposure to formaldehyde may occur by breathing contaminated indoor air, tobacco smoke, or ambient urban air. Acute (short-term) and chronic (long-term) inhalation exposure to formaldehyde in humans can result in respiratory symptoms, and eye, nose, and throat irritation. Limited human studies have reported an association between formaldehyde exposure and lung and nasopharyngeal cancer. Animal inhalation studies have reported an increased incidence of nasal squamous cell cancer. EPA considers formaldehyde a probable human carcinogen (Group B1).

Methanol

Methanol is released to the environment during industrial uses and naturally from volcanic gases, vegetation, and microbes. Exposure may occur from ambient air and during the use of solvents. Acute (short-term) or chronic (long-term) exposure of humans to methanol by inhalation or ingestion may result in blurred vision, headache, dizziness, and nausea. No information is available on the reproductive, developmental, or carcinogenic effects of methanol in humans. Birth defects have been observed in the offspring of rats and mice exposed to methanol by inhalation. EPA has not classified methanol with respect to carcinogenicity.

Methanol is primarily used as an industrial solvent for inks, resins, adhesives, and dyes. It is also used as a solvent in the manufacture of cholesterol, streptomycin, vitamins, hormones, and other pharmaceuticals. Methanol is also used as an antifreeze for automotive radiators, an ingredient of gasoline (as an antifreezing agent and octane booster), and as fuel for picnic stoves. Methanol is also an ingredient in paint and varnish removers. Methanol is also used as an alternative motor fuel.

All HAPs have other non-carcinogenic chronic and acute effects. These adverse health effects may be associated with a wide range of ambient concentrations and exposure times and are influenced by source-specific characteristics such as emission rates and local meteorological conditions. Health impacts are also dependent on multiple factors that affect variability in humans such as genetics, age, health status (e.g., the presence of pre-existing disease) and lifestyle. As stated previously, *there are no federal or state ambient air quality standards for these specific chemicals*. For a complete discussion of the known health effects of each compound refer to the IRIS database located at www.epa.gov/iris.

AIR QUALITY IMPACT ANALYSIS

Modeling was not required of this source due to the fact that the facility is not subject to 45CSR14 (Permits for Construction and Major Modification of Major Stationary Sources of Air Pollutants) as seen in the table listed in the Regulatory Discussion Section.

SOURCE AGGREGATION

“Building, structure, facility, or installation” is defined as all the pollutant emitting activities which belong to the same industrial grouping, are located on one or more contiguous and adjacent properties, and are under the control of the same person.

The Nichols Compressor Station is located in Tyler County and will be operated by Antero.

1. The Nichols Compressor Station will operate under SIC code 4922 (Pipeline Transportation of Natural Gas). There are other compressor stations operated by Antero that share the same two-digit major SIC code of 49 for natural gas transmission. Therefore, the Nichols Compressor Station does share the same SIC code as other Antero compressor stations.
2. “Contiguous or Adjacent” determinations are made on a case by case basis. These determinations are proximity based, and it is important to focus on this and whether or not it meets the common sense notion of a plant. The terms “contiguous” or “adjacent” are not defined by USEPA. Contiguous has a dictionary definition of being in actual contact; touching along a boundary or at a point. Adjacent has a dictionary definition of not distant; nearby; having a common endpoint or border.

There are no Antero properties in question that are considered to be on contiguous or adjacent property with the Nichols Compressor Station.

3. Common control. The natural gas well sites that supply the incoming natural gas streams to the Nichols Compressor Station are owned and operated by Antero Resources.

Because the facilities are not considered to be on contiguous or adjacent properties, the emissions from the Nichols Compressor Station should not be aggregated with other facilities in determining major source or PSD status.

MONITORING OF OPERATIONS

Antero will be required to perform the following monitoring:

- Monitor and record quantity of natural gas consumed for all engines and combustion sources.
- Monitor all applicable requirements of 40CFR60 Subparts JJJJ and OOOO.
- Monitor the presence of the flare pilot flame with a thermocouple or equivalent.

Antero will be required to perform the following recordkeeping:


- Maintain records of the amount of natural gas consumed and hours of operation for all engines and combustion sources.
- Maintain records of testing conducted in accordance with the permit. Said records shall be maintained on-site or in a readily accessible off-site location
- Maintain the corresponding records specified by the on-going monitoring requirements of and testing requirements of the permit.
- Maintain records of the visible emission opacity tests conducted per the permit.
- Maintain a record of all potential to emit (PTE) HAP calculations for the entire facility. These records shall include the natural gas compressor engines and ancillary equipment.
- Maintain records of all applicable requirements of 40CFR60 Subparts JJJJ and OOOO.
- Maintain records of the flare design evaluation.
- The records shall be maintained on site or in a readily available off-site location maintained by Antero for a period of five (5) years.

CHANGES TO PERMIT R13-3201A

- Section 1.0 (Emission Units) – Addition of catalytic heater (47E).
- Section 4.0 (Source Specific Requirements) – Addition of quarterly AVO inspections of facility components to detect fugitive leaks.
- Section 5.1.1 – Established annual limitation of natural gas consumption rate for engines (CE-01 – CE-11). This limit constitutes this source as a synthetic minor for NO_x and CO.
- Section 5.1.2 – Change in emission limits due to operational conditions of NSCR and annual throughput limitation.
- Section 8.1.6.c – Changed the requirement to apply to storage tanks T01 – T05, instead of just storage tanks T04 and T05.
- Section 9.1.3 – Addition of fugitive escape language.
- Section 11 – Updated this section to include the current applicable requirements of 40CFR60 Subpart JJJJ.

RECOMMENDATION TO DIRECTOR

The information provided in the permit application indicates that Antero meets all the requirements of applicable regulations. Therefore, impact on the surrounding area should be minimized and it is recommended that the Nichols Compressor Station should be granted a 45CSR13 modification permit for their facility.



Jerry Williams, B.E.
Engineer

Oct. 7, 2015

Date