



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475

Earl Ray Tomblin, Governor
Randy C. Huffinan, Cabinet Secretary
www.dep.wv.gov

November 13, 2015

CERTIFIED MAIL
91 7199 9991 7034 1379 8204

John P. Whittington
Executive Vice President
3660 Grandview Parkway, Ste. 200
Birmingham, AL 35243

RE: Approved Registration G65-C556
Rehabilitation Hospital Corp. Of America, LLC
HealthSouth Southern Hills Rehabilitation Hospital
Plant ID No. 055-00138

Dear Mr. Whittington:

The Director has determined that the submitted Registration Application and construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G65-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.5.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.
Engineer

Enclosures: General Permit Registration G65-C556
General Permit G65-C

West Virginia Department of Environmental Protection
Earl Ray Tomblin
Governor

Division of Air Quality

Randy C. Huffman
Cabinet Secretary

Class I General Permit G65-C Registration to Construct



for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to
construct the stationary sources of air pollutants identified herein in accordance
with all terms and conditions of General Permit G65-C.*

G65-C556

Issued to:
Rehabilitation Hospital Corporation of America, LLC
HealthSouth Southern Hills Rehabilitation Hospital
055-00138

A blue ink signature of William F. Durham, written in a cursive style.

William F. Durham
Director

Issued: November 13, 2015 • Effective: November 13, 2015

Facility Location: Princeton, Mercer County, West Virginia
Mailing Address: 3660 Grandview Parkway, Ste. 200, Birmingham, AL 35243
Facility Description: Hospital
SIC Codes: 8069
UTM Coordinates: 490.157 km Easting • 4135.165 km Northing • Zone 17
Registration Type: Construction
Description of Change: Construction of an Emergency Generator

Subject to 40CFR60 Subpart IIII? **Yes** Certified? **Yes**
Subject to 40CFR60 Subpart JJJJ? **No**

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class I General Permit G65-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	Volvo TWD1643GE	2015	917 bhp / 1800 rpm
TO1	Fuel Tank	2015	1,000 Gallons

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide	
	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	10.46	2.61	0.76	0.19