



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone 304/926-0475

Joe Manchin, III, Governor  
Randy C. Huffman, Cabinet Secretary  
www.wvdep.org

October 15, 2015

CERTIFIED MAIL  
91 7199 9991 7035 6613 3051

Mr. Thomas Beal  
AC&S, Inc.  
P.O. Box 335  
Nitro, WV 25143


RE: Approved Registration G60-C080  
AC&S, Inc.  
Nitro Facility  
079-00014

Dear Mr. Beal:

The Director has determined that the submitted Registration Application and proposed construction and operation of a natural gas compressor station demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G60-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Monitoring Requirements, Testing Requirements, Recordkeeping Requirements, and the Reporting Requirements.

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1258.

Sincerely,  
  
Caraline Griffith  
Permit Engineer

Enclosures: Registration G60-C080  
General Permit G60-C

c: Jennie Henthorn - Contact  
Henthorn Environmental Services

Eric Miller  
AC&S, Inc.

*West Virginia Department of Environmental Protection*  
Earl Ray Tomblin  
Governor

*Division of Air Quality*

Randy C. Huffman  
Cabinet Secretary

## Class II General Permit G60-C Registration to Construct



for the  
Prevention and Control of Air Pollution in regard to the  
Construction, Modification, Relocation, Administrative Update and  
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to  
construct the stationary sources of air pollutants identified herein in accordance  
with all terms and conditions of General Permit G60-C.*

**G60-C080**

Issued to:  
**AC&S, Inc.**  
Nitro Facility  
079-00014

A blue ink signature of William F. Durham, written in a cursive style, positioned above a horizontal line.

*William F. Durham*  
Director

*Issued: October 15, 2015*

Facility Location: Nitro, Putnam County, West Virginia  
Mailing Address: P.O. Box 335  
Nitro, WV 25143  
Facility Description: Chemical and Allied Products  
SIC Codes: 2879  
UTM Coordinates: 426.1 km Easting • 4254.1 km Northing • Zone 17  
Registration Type: Construction  
Description of Change: After-the-fact registration for a Caterpillar D40-4 emergency generator.

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [ §§ 22B-1-1 et seq. ], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is not subject to 45CSR30.*

---

**All registered facilities under Class II General Permit G60-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.**

The following sections of Class II General Permit G60-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

**Emission Units**

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
E-GEN-01	Caterpillar D40-4	2006	1800

**Emission Limitations**

Source ID#	Nitrogen Oxides		Carbon Monoxide		Volatile Organic Compounds	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
E-GEN-01	0.82	0.21	0.18	0.05	0.07	0.02
<b>TOTAL</b>	<b>0.82</b>	<b>0.21</b>	<b>0.18</b>	<b>0.05</b>	<b>0.07</b>	<b>0.02</b>