



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street, S.E.  
Charleston, WV 25304

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

October 18, 2016

Donald Sult  
Vice President - Operations  
Continental Brick Company  
154 Charles Town Road  
Martinsburg, WV 25401

Re: Permit Applicability Determination  
Martinsburg Facility  
Berkeley County, WV  
Determination No. PD16-053  
Plant ID No. 003-00002

Dear Mr. Sult:

It has been determined that a permit will not be required under 45CSR13 for the proposed installation of a veneer saw at the above referenced facility. This determination is based on information included with your Permit Determination Form (PDF) received on September 7, 2016, which indicates that the increase in emissions will not exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility, may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer