west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone: (304) 926-0475 • FAX: (304) 926-0479

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.dep.wv.gov

October 14, 2016

CERTIFIED MAIL
91 7199 9991 7035 6610 3849

Greg Darby, President
PO Box 968
Beckley, WV 25802

RE: Little General Store, Inc.
Facility #2030
Permit Application G65-C561
Plant ID No. 019-00117

Dear Mr. Darby:

Your application for a permit as required by Section 5 of 45CSR13 - "Permits for Construction, Modification, Relocation and Operation of Stationary Sources of Air Pollutants, Notification Requirements, Temporary Permit, General Permit, and Procedures for Evaluation" has been approved. The enclosed permit G65-C561 is hereby issued pursuant to Subsection 5.7 of 45CSR13. Please be aware of the notification requirements in the permit which pertain to commencement of construction, modification, or relocation activities; startup of operations; and suspension of operations.

The source is not subject to 45CSR30.

In accordance with 45CSR22 - Air Quality Management Fee Program, the permittee shall not operate nor cause to operate the permitted facility or other associated facilities on the same or contiguous sites comprising the plant without first obtaining and having in current effect a Certificate to Operate (CTO). Such Certificate to Operate (CTO) shall be renewed annually, shall be maintained on the premises for which the Certificate has been issued, and shall be made immediately available for inspection by the Secretary or his/her duly authorized representative.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §§22-5-14.

Should you have any questions or comments, please contact me at (304) 926-0499, extension 1212.

Sincerely,

Thornton E. Martin Jr.

Thornton E. Martin Jr.
Permit Engineer

West Virginia Department of Environmental Protection

Earl Ray Tomblin
Governor

Division of Air Quality

Randy C. Huffman
Cabinet Secretary

Class I General Permit
G65-C Registration to Construct

for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

The permittee identified at the facility listed below is authorized to construct the stationary sources of air pollutants identified herein in accordance with all terms and conditions of General Permit G65-C.

G65-C561

Issued to:

Little General Store, Inc.
Facility #2030
019-00117

William F. Durham
Director

Effective: October 14. 2016

This Class I General Permit Registration does not affect any other 45CSR13 permits.

Facility Location:	Fayetteville, Fayette County, West Virginia
Mailing Address:	PO Box 968, Beckley, West Virginia 25802
Facility Description:	Emergency Generator
SIC Codes:	5541
UTM Coordinates:	490.85 km Easting • 4212.13 km Northing • Zone 17
Registration Type:	Construction
Description of Change:	Permit operation of an emergency generator used during power outages.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

Unless otherwise stated WVDEP DAQ did not determine whether the permittee is subject to an area source air toxics standard requiring Generally Achievable Control Technology (GACT) promulgated after January 1, 2007 pursuant to 40 CFR 63, including the area source air toxics provisions of 40 CFR 63, Subpart HH and 40 CFR 63, Subpart ZZZZ.

All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class I General Permit G65-C apply to the registrant:

Section 5	Reciprocating Internal Combustion Engines (R.I.C.E.)	X
Section 6	Tanks	X
Section 7	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)	X
Section 8	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)	☐

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	Caterpillar, 1991, Ser. No. 85Z08148	2014	305/1800
T-01	Fuel Tank, 265 gallons, #2FO	2014	N/A

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide		Particulate Matter < 10 microns	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	5.34	1.33	6.58	1.64	0.31	0.077