



---

**west virginia department of environmental protection**

---

Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone 304/926-0475

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
www.wvdep.org

September 24, 2015

CERTIFIED MAIL  
91 7199 9991 7034 1379 8174

Brian Sheppard  
Vice President, Pipeline Operations  
445 West Main Street  
Clarksburg, WV 26301

RE: Approved Registration G60-C077  
Dominion Transmission, Inc.  
Grantsville G&P  
Plant ID No. 013-00016

Dear Mr. Sheppard :

The Director has determined that the submitted Registration Application and proposed construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G60-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.6.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer

Enclosures: General Permit Registration G60-C077  
General Permit G60-C



Facility Location: Grantsville, Calhoun County, West Virginia  
Mailing Address: 445 West Main Street, Clarksburg, WV 26301  
Facility Description: Office Building Emergency Generator  
SIC Codes: 8741  
UTM Coordinates: 491.70 km Easting • 4308.02 km Northing • Zone 17  
Registration Type: Construction  
Description of Change: Installation of one natural gas-fired generator to be used in emergency situations.

Subject to 40CFR60 Subpart IIII? No  
Subject to 40CFR60 Subpart JJJJ? Yes, Certified? Yes

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [ §§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is not subject to 45CSR30.*

---

**All registered facilities under Class II General Permit G60-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.**

The following sections of Class II General Permit G60-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

**Emission Units**

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	Generac QT048	2015	82.1 bhp/1800

**Reciprocating Internal Combustion Engines (R.I.C.E.) Information**

Emission Unit ID	Subject to 40CFR60 Subpart IIII?	Subject to 40CFR60 Subpart JJJJ?	Subject to Sections 5.1.4/5.2.1 (Catalytic Reduction Device)
EG-1	No	Yes	No

**Emission Limitations**

Source ID#	Nitrogen Oxides		Carbon Monoxide		Volatile Organic Compounds	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	0.46	0.11	17.25	4.31	0.29	0.07