



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.wvdep.gov

August 27, 2015

CERTIFIED MAIL
91 7199 9991 7034 1379 8082

Jaime Light
Director of Plant Operations
202 Maplewood Avenue
Ronceverte, WV 24970

RE: Approved Registration G60-C075A
Greenbrier Valley Medical Center
Ronceverte Facility
Plant ID No. 025-00109

Dear Mr. Light:

The Director has determined that the submitted Registration Application and proposed construction and operation of two emergency generators demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G60-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.6.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

A handwritten signature in blue ink, appearing to read "William T. Rothwell II".

William T. Rothwell II, P.E.
Engineer

Enclosures: General Permit Registration G60-C075A
General Permit G60-C

West Virginia Department of Environmental Protection
Earl Ray Tomblin
Governor

Division of Air Quality

Randy C. Huffman
Cabinet Secretary

Permit to Administratively Update



for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to
construct the stationary sources of air pollutants identified herein in accordance
with all terms and conditions of General Permit G60-C.*

G60-C075A

Issued to:

**Greenbrier Valley Medical Center
Ronceverte Facility
025-00109**

A handwritten signature in blue ink, appearing to read "William F. Durham", written over a horizontal line.

William F. Durham
Director

Effective: August 27, 2015

Facility Location: Ronceverte, Greenbrier County, West Virginia
Mailing Address: 202 Maplewood Avenue, Ronceverte, WV 24970
Facility Description: General Medical and Surgical Hospitals
SIC Codes: 8062
UTM Coordinates: 446.649 km Easting • 4180.825 km Northing • Zone 17
Registration Type: Construction
Description of Change: Class I Administrative update to correct the facility's source destination.

Subject to 40CFR60 Subpart IIII? No
Subject to 40CFR60 Subpart JJJJ? No

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

Emission Limitations

Emission Unit	Pollutant	Maximum Hourly Emissions (lb/hr)	Maximum Annual Emissions (tpy)
EG-1 Detroit Diesel, 8V-92TA	Nitrogen Oxides	14.11	3.53
	Carbon Monoxide	7.61	1.90
	Volatile Organic Compounds	0.16	0.04
	Sulfur Dioxide	2.40	0.60
	Particulate Matter	1.42	0.35
	Total HAP's	0.01	0.002
EG-2 Cummins, NTA855-G2	Nitrogen Oxides	9.10	2.27
	Carbon Monoxide	1.23	0.31
	Volatile Organic Compounds	0.07	0.02
	Sulfur Dioxide	0.65	0.16
	Particulate Matter	0.31	0.08
	Total HAP's	0.005	0.001