



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.wvdep.org

September 24, 2015

CERTIFIED MAIL
91 7199 9991 7034 1379 8181

Brian Sheppard
Vice President, Pipeline Operations
445 West Main Street
Clarksburg, WV 26301

RE: Approved Registration G60-C078
Dominion Transmission, Inc.
Weston G&P
Plant ID No. 041-00075

Dear Mr. Sheppard :

The Director has determined that the submitted Registration Application and proposed construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G60-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.6.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.
Engineer

Enclosures: General Permit Registration G60-C078
General Permit G60-C

Class II General Permit G60-C Registration to Construct



for the
Prevention and Control of Air Pollution in regard to the
Construction, Modification, Relocation, Administrative Update and
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to
construct the stationary sources of air pollutants identified herein in accordance
with all terms and conditions of General Permit G60-C.*

G60-C078

Issued to:
Dominion Transmission, Inc.
Weston G&P
041-00075

A blue ink signature of William F. Durham, written in a cursive style, positioned above a horizontal line.

William F. Durham
Director

Issued: September 24, 2015

Effective: September 24, 2015

Facility Location: Weston, Lewis County, West Virginia
Mailing Address: 445 West Main Street, Clarksburg, WV 26301
Facility Description: Office Building Emergency Generator
SIC Codes: 8741
UTM Coordinates: 543.61 km Easting • 4328.90 km Northing • Zone 17
Registration Type: Construction
Description of Change: Installation of one natural gas-fired generator to be used in emergency situations.

Subject to 40CFR60 Subpart IIII? No
Subject to 40CFR60 Subpart JJJJ? Yes, Certified? Yes

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class II General Permit G60-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class II General Permit G60-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	Generac QT048	2015	82.1 bhp/1800

Reciprocating Internal Combustion Engines (R.I.C.E.) Information

Emission Unit ID	Subject to 40CFR60 Subpart IIII?	Subject to 40CFR60 Subpart JJJJ?	Subject to Sections 5.1.4/5.2.1 (Catalytic Reduction Device)
EG-1	No	Yes	No

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide		Volatile Organic Compounds	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	0.46	0.11	17.25	4.31	0.29	0.07