



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone 304/926-0475

Earl Ray Tomblin, Governor
Randy C. Huffman, Cabinet Secretary
www.wvdep.gov

September 3, 2015

CERTIFIED MAIL

91 7199 9991 7034 1378 6171

Col. Joseph P. Stephens
Construction and Facilities Management Officer
West Virginia Army National Guard
1703 Coonskin Drive
Charleston, WV 25311

RE: Approved Registration G65-C553
Camp Dawson
Plant ID No. 045-00147

Dear Col. Stephens:

The Director has determined that the submitted Registration Application and proposed construction and operation of two emergency generators demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G60-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.6.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1214.

Sincerely,

Edward S. Andrews, P.E.
Engineer

Enclosures: General Permit Registration G60-C042A
General Permit G60-C

Facility Location: 361 22 Mine Road
Holden, Logan County, West Virginia
Mailing Address: 1703 Coonskin Drive
Charleston, WV 25311
Facility Description: Army National Guard Readiness Center
NAICS Codes: 928110
UTM Coordinates: 402.09 km Easting • 4,180.02 km Northing • Zone 17
Registration Type: Construction
Description of Change: This action is for the installation of a diesel generator set with belly tank.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

The source is not subject to 45CSR30.

All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.

The following sections of Class I General Permit G65-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart III)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJ)

Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	Caterpillar C32 ATAAAC, 2015 Model Year Engine	2015	1474

Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide		Volatile Organic Compounds	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	16.0	4.0	0.42	0.11	0.03	0.12