



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street, S.E.  
Charleston, WV 25304

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
www.dep.wv.gov

August 27, 2015

**CERTIFIED MAIL**  
91 7199 9991 7034 1379 8075

Louise McAtee  
Office Manager  
Huttonsville Public Service District  
1469 Elkwater Fork Road  
Huttonsville, WV 26273

Re: Permit Applicability Determination  
Water Treatment Plant  
Randolph County, WV  
Determination No. PD15-074  
Plant ID No. 083-00136

Dear Ms. McAtee:

It has been determined that a permit will be required under 45CSR13 for your installation and operation of a 1,005 hp Caterpillar Model C27ATAAC diesel fired generator at the above referenced facility. This determination is based on information included with your Permit Determination Form (PDF) received on August 24, 2015, which indicates that the increase in emissions will exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY or more, or 144 pounds per calendar day of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

The appropriate application forms which need to be completed can be obtained from the WVDEP website at <http://www.dep.wv.gov>. Submit the completed forms, \$1,000.00 permit application fee, and any other applicable fees to the above address. If you should have questions concerning which forms are needed, or have trouble downloading, please call the Permitting Secretary at (304) 926-0475. Please address this matter as soon as possible to ensure expediency of the permit review process.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

  
William T. Rothwell II, P.E.  
Engineer